

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Lipiec 2021**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/07/2021	1	0.39	33.44	0.26	78.86	0.41	2.44	2.38	8.34	176.38	869.3	24:00:00
02/07/2021	1	0.40	31.50	0.26	84.87	0.40	1.40	2.41	8.25	176.76	872.5	24:00:00
03/07/2021	1	0.38	31.48	0.26	82.25	0.38	2.35	2.34	8.27	176.20	870.5	24:00:00
04/07/2021	1	0.28	31.43	0.26	79.96	0.40	2.44	2.41	8.24	176.74	868.4	24:00:00
05/07/2021	1	0.25	30.68	0.26	62.05	0.39	1.00	2.92	8.58	172.84	869.4	19:59:30
06/07/2021	1	0.34	32.24	0.26	79.14	0.41	2.31	0.87	8.17	177.39	875.7	24:00:00
07/07/2021	1	0.25	29.91	0.26	88.02	0.42	1.14	0.65	8.12	178.49	871.9	23:48:20
08/07/2021	1	0.30	31.52	0.26	77.27	0.42	1.32	0.55	8.42	176.25	872.3	21:04:10
09/07/2021	1	0.29	32.49	0.27	69.59	0.46	2.26	2.04	8.62	173.25	869.4	21:42:30
10/07/2021	1	0.32	34.95	0.28	75.94	0.45	2.12	0.32	8.34	175.27	873.6	23:19:30
11/07/2021	1	0.26	33.82	0.26	92.68	0.47	1.13	3.59	8.24	176.43	868.3	24:00:00
12/07/2021	1	0.26	31.61	0.26	84.10	0.46	2.25	3.11	8.16	176.26	875.7	24:00:00
13/07/2021	1	0.25	36.04	0.26	85.47	0.43	2.89	2.39	9.18	162.37	871.0	16:29:10
14/07/2021	1	0.28	36.23	0.27	77.77	0.43	2.20	3.61	8.51	176.24	870.6	24:00:00
15/07/2021	1	0.27	34.97	0.26	60.79	0.39	1.98	4.29	9.84	164.11	863.9	13:56:10
16/07/2021	1	0.27	33.44	0.26	79.84	0.39	2.22	3.39	8.31	175.68	871.2	24:00:00
17/07/2021	1	0.23	30.02	0.26	89.21	0.40	2.98	3.15	8.23	175.82	870.7	24:00:00
18/07/2021	1	0.24	26.46	0.26	79.32	0.39	2.70	3.10	8.35	174.00	863.9	24:00:00
19/07/2021	1	0.25	23.77	0.27	64.97	0.40	2.22	4.59	8.48	172.64	862.5	23:00:30
20/07/2021	1	0.23	26.25	0.26	70.62	0.38	1.49	6.17	8.34	172.58	861.3	24:00:00
21/07/2021	1	0.24	24.87	0.26	68.91	0.40	2.78	5.41	8.33	173.06	864.6	24:00:00
22/07/2021	1	0.23	27.24	0.26	70.97	0.40	1.45	5.20	8.33	173.60	862.9	24:00:00
23/07/2021	1	0.24	23.62	0.26	67.11	0.40	1.07	5.05	8.28	173.83	867.0	24:00:00
24/07/2021	1	0.23	29.68	0.26	68.63	0.41	2.53	4.91	8.25	175.58	864.0	24:00:00
25/07/2021	1	0.23	26.95	0.25	62.90	0.40	1.34	4.77	8.09	174.53	863.1	24:00:00
26/07/2021	1	0.25	22.89	0.25	58.23	0.40	1.97	6.79	7.93	174.76	868.5	18:59:40
27/07/2021	1	0.18	24.48	0.43	76.11	0.65	1.94	9.68	12.67	174.34	862.2	18:51:00
28/07/2021	1	0.28	24.71	0.25	65.29	0.41	0.94	4.25	7.93	175.89	866.1	24:00:00
29/07/2021	1	0.26	28.25	0.25	53.27	0.42	1.97	3.03	8.02	175.52	864.2	23:32:50
30/07/2021	1	0.25	29.20	0.25	61.85	0.43	2.28	2.83	7.94	176.16	861.1	23:02:50
31/07/2021	1	0.23	29.87	0.25	67.50	0.41	2.34	2.61	7.92	176.00	858.0	24:00:00
<b>Min</b>	<b>1</b>	<b>0.18</b>	<b>22.89</b>	<b>0.25</b>	<b>53.27</b>	<b>0.38</b>	<b>0.94</b>	<b>0.32</b>	<b>7.92</b>	<b>162.37</b>	<b>858.0</b>	
<b>Max</b>	<b>1</b>	<b>0.40</b>	<b>36.23</b>	<b>0.43</b>	<b>92.68</b>	<b>0.65</b>	<b>2.98</b>	<b>9.68</b>	<b>12.67</b>	<b>178.49</b>	<b>875.7</b>	
<b>Sr.</b>	<b>1</b>	<b>0.27</b>	<b>29.81</b>	<b>0.27</b>	<b>73.66</b>	<b>0.42</b>	<b>1.98</b>	<b>3.51</b>	<b>8.47</b>	<b>174.48</b>	<b>867.5</b>	<b>29d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>07:46:10</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>01:30</b>				