

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Sierpień 2021**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/08/2021	1	0.25	32.64	0.25	67.44	0.41	1.37	3.05	7.89	175.96	857.1	24:00:00
02/08/2021	1	0.24	29.37	0.25	60.47	0.42	1.62	3.09	7.96	175.42	858.5	24:00:00
03/08/2021	1	0.31	29.60	0.26	78.67	0.41	2.39	6.83	8.14	173.13	859.0	20:27:40
04/08/2021	1	0.23	31.10	0.25	78.30	0.41	0.00	3.33	7.91	176.71	861.6	24:00:00
05/08/2021	1	0.26	29.71	0.26	80.89	0.42	0.42	2.94	8.00	176.28	861.3	24:00:00
06/08/2021	1	0.31	28.51	0.26	76.41	0.43	2.28	2.93	8.20	175.68	860.3	24:00:00
07/08/2021	1	0.26	32.08	0.26	83.00	0.43	0.52	2.71	8.27	177.02	862.6	24:00:00
08/08/2021	1	0.26	32.26	0.28	83.34	0.45	1.68	2.57	8.50	177.18	862.4	24:00:00
09/08/2021	1	0.25	32.78	0.27	92.67	0.44	1.15	2.64	8.67	177.41	857.8	24:00:00
10/08/2021	1	0.24	31.42	0.28	102.81	0.45	0.00	2.66	8.79	179.26	858.4	24:00:00
11/08/2021	1	0.29	25.75	0.27	63.17	0.45	1.14	2.41	8.99	176.72	860.3	23:37:50
12/08/2021	1	0.26	26.20	0.28	67.94	0.45	2.16	2.60	9.81	165.74	857.3	12:31:40
13/08/2021	1	0.25	28.82	0.28	70.55	0.45	2.43	2.59	9.18	174.05	858.0	24:00:00
14/08/2021	1	0.25	29.48	0.28	88.24	0.46	2.77	2.71	9.25	175.42	858.6	23:45:40
15/08/2021	1	0.25	31.05	0.28	92.43	0.44	1.38	2.66	9.27	176.57	857.1	23:35:30
16/08/2021	1	0.25	28.87	0.29	67.26	0.47	1.39	2.65	10.03	165.67	857.1	13:33:30
17/08/2021	1	0.26	28.47	0.28	73.99	0.47	2.47	2.72	9.44	173.69	860.5	24:00:00
18/08/2021	1	0.25	27.68	0.28	62.06	0.47	1.17	2.55	9.48	173.72	861.6	24:00:00
19/08/2021	1	0.26	28.17	0.28	61.24	0.48	1.05	2.59	9.52	174.09	857.2	24:00:00
20/08/2021	1	0.26	33.97	0.29	67.19	0.48	0.96	2.61	9.73	175.01	858.1	23:57:00
21/08/2021	1	0.26	28.83	0.29	70.21	0.48	0.84	2.62	9.90	173.79	859.5	24:00:00
22/08/2021	1	0.36	17.06	0.30	41.38	0.50	0.44	<b>11.82</b>	10.36	166.86	858.0	20:14:00
23/08/2021	1	0.33	17.52	0.29	46.47	0.48	0.54	4.47	10.13	171.08	857.0	21:44:50
24/08/2021	1	0.27	29.18	0.30	56.16	0.50	0.62	3.88	10.13	171.90	857.0	24:00:00
25/08/2021	1	0.26	26.04	0.30	55.59	0.48	0.62	3.65	10.19	168.07	857.0	20:46:00
26/08/2021	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.12	156.91	PIEC O	00:00:00
27/08/2021	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	12.08	89.47	PIEC O	00:00:00
28/08/2021	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	16.25	64.83	PIEC O	00:00:00
29/08/2021	1	Niedostępny	Niedostępny	Niedostępny	Niedostępny	Niedostępny	Niedostępny	Niedostępny	16.09	54.74	Niedostępny	00:00:00
30/08/2021	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	00:00:00
31/08/2021	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	Nieważne	Nieważne	PIEC O	00:00:00
<b>Min</b>	<b>1</b>	<b>0.23</b>	<b>17.06</b>	<b>0.25</b>	<b>41.38</b>	<b>0.41</b>	<b>0.00</b>	<b>2.41</b>	<b>7.89</b>	<b>54.74</b>	<b>857.0</b>	
<b>Max</b>	<b>1</b>	<b>0.36</b>	<b>33.97</b>	<b>0.30</b>	<b>102.81</b>	<b>0.50</b>	<b>2.77</b>	<b>11.82</b>	<b>16.25</b>	<b>179.26</b>	<b>862.6</b>	
<b>Sr.</b>	<b>1</b>	<b>0.27</b>	<b>28.66</b>	<b>0.28</b>	<b>71.52</b>	<b>0.45</b>	<b>1.26</b>	<b>3.41</b>	<b>9.77</b>	<b>162.50</b>	<b>858.9</b>	<b>23d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>				<b>12:13:40</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>03:30</b>				