

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Kwiecień 2021**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/04/2021	1	0.48	30.71	2.68	85.73	0.31	1.08	0.32	10.45	170.99	874.5	24:00:00
02/04/2021	1	0.45	22.89	0.30	65.18	0.31	0.90	0.28	10.35	168.98	872.8	24:00:00
03/04/2021	1	0.80	26.30	0.30	83.30	0.33	0.72	2.72	10.03	172.55	884.3	24:00:00
04/04/2021	1	0.80	25.66	0.30	75.87	0.33	0.67	2.81	10.09	171.44	885.5	24:00:00
05/04/2021	1	0.48	28.97	0.39	64.80	0.33	0.88	2.86	10.07	171.15	876.9	24:00:00
06/04/2021	1	0.80	26.65	0.29	62.65	0.32	0.72	2.75	9.90	171.62	883.3	24:00:00
07/04/2021	1	0.73	24.02	0.29	69.18	0.32	0.71	2.73	9.89	171.54	885.1	24:00:00
08/04/2021	1	0.52	21.30	0.29	69.10	0.30	0.79	5.58	14.35	146.81	878.1	08:19:50
09/04/2021	1	0.48	29.69	0.30	73.77	0.30	0.93	5.80	10.09	168.85	877.3	24:00:00
10/04/2021	1	0.56	26.76	0.29	74.11	0.28	0.79	2.94	9.96	170.34	885.5	24:00:00
11/04/2021	1	0.60	27.65	0.30	70.21	0.30	0.78	3.18	10.06	170.12	884.7	23:57:00
12/04/2021	1	0.55	24.12	0.30	61.10	0.28	0.80	2.98	10.25	168.79	881.2	24:00:00
13/04/2021	1	0.61	21.13	0.30	55.85	0.27	0.76	2.82	10.29	167.77	881.3	24:00:00
14/04/2021	1	0.63	9.87	0.31	60.42	0.25	0.54	6.82	13.59	147.38	867.2	12:09:20
15/04/2021	0	0.31	24.12	7.14	35.28	0.47	0.54	3.30	10.60	165.61	868.8	24:00:00
16/04/2021	1	0.53	27.48	4.77	44.45	0.45	0.50	2.07	10.63	164.88	871.5	24:00:00
17/04/2021	1	0.67	21.00	0.31	54.54	0.27	0.61	0.44	10.56	165.55	860.4	24:00:00
18/04/2021	1	0.45	21.41	0.36	53.92	0.27	0.70	0.35	10.61	164.78	856.1	24:00:00
19/04/2021	1	0.52	20.92	0.34	54.24	0.27	0.56	0.33	10.61	165.20	856.8	24:00:00
20/04/2021	1	0.66	20.18	0.30	56.55	0.26	0.61	1.29	11.66	158.61	855.3	20:01:40
21/04/2021	1	0.66	19.42	0.30	56.21	0.26	0.53	1.37	10.48	165.60	855.1	24:00:00
22/04/2021	1	0.66	20.01	0.30	56.54	0.25	0.59	0.88	10.22	166.05	860.5	24:00:00
23/04/2021	1	0.76	19.42	0.29	69.71	0.24	0.58	0.69	9.95	168.80	867.4	24:00:00
24/04/2021	1	0.54	21.27	0.30	62.04	0.25	0.55	0.53	10.14	166.71	855.7	24:00:00
25/04/2021	1	0.73	21.36	0.29	73.09	0.25	0.57	0.49	9.85	168.72	857.7	24:00:00
26/04/2021	1	0.72	15.00	0.29	69.67	0.25	0.52	2.05	10.20	167.09	856.7	21:35:00
27/04/2021	1	0.50	19.97	0.29	59.45	0.26	0.91	1.68	9.89	169.37	886.0	24:00:00
28/04/2021	1	0.60	19.30	0.29	57.62	0.26	0.69	1.38	9.76	170.05	888.6	24:00:00
29/04/2021	1	0.62	26.19	0.29	65.68	0.28	0.99	1.34	9.83	170.94	885.7	24:00:00
30/04/2021	1	0.71	24.27	0.29	61.00	0.26	1.03	1.27	9.95	170.62	879.0	24:00:00
<b>Min</b>	<b>0</b>	<b>0.31</b>	<b>9.87</b>	<b>0.29</b>	<b>35.28</b>	<b>0.24</b>	<b>0.50</b>	<b>0.28</b>	<b>9.76</b>	<b>146.81</b>	<b>855.1</b>	
<b>Max</b>	<b>1</b>	<b>0.80</b>	<b>30.71</b>	<b>7.14</b>	<b>85.73</b>	<b>0.47</b>	<b>1.08</b>	<b>6.82</b>	<b>14.35</b>	<b>172.55</b>	<b>888.6</b>	
<b>Sr.</b>	<b>1</b>	<b>0.60</b>	<b>22.90</b>	<b>0.76</b>	<b>63.38</b>	<b>0.29</b>	<b>0.72</b>	<b>2.14</b>	<b>10.48</b>	<b>166.90</b>	<b>872.6</b>	<b>28d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>14:02:50</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>01:30</b>				