

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Luty 2022**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/02/2022	1	1.91	26.94	1.45	24.08	0.21	0.76	2.34	9.32	160.01	882.0	19:29:50
02/02/2022	1	2.26	28.19	0.67	26.31	0.21	0.77	2.65	8.93	166.66	878.8	24:00:00
03/02/2022	1	2.24	30.44	1.63	23.11	0.21	0.79	2.50	9.17	165.13	874.6	23:56:10
04/02/2022	1	1.49	22.20	0.79	21.98	0.19	0.77	2.43	9.47	158.03	863.3	24:00:00
05/02/2022	1	1.64	24.66	2.10	18.72	0.19	0.76	2.45	9.46	159.08	859.1	24:00:00
06/02/2022	1	1.82	28.96	0.97	23.48	0.20	0.76	2.52	9.12	166.38	876.4	24:00:00
07/02/2022	1	1.68	28.52	1.20	25.08	0.20	0.77	2.41	9.24	164.76	882.1	21:36:00
08/02/2022	1	1.85	25.21	1.77	24.36	0.22	0.79	2.31	9.19	166.49	888.3	24:00:00
09/02/2022	1	1.56	25.94	1.42	24.73	0.20	0.78	2.27	9.25	165.82	884.7	24:00:00
10/02/2022	1	0.85	18.99	0.99	29.50	0.14	0.67	2.03	7.62	166.39	885.5	24:00:00
11/02/2022	0	0.28	24.77	1.40	75.32	0.07	0.70	2.55	9.71	164.59	887.3	24:00:00
12/02/2022	0	0.72	24.53	0.91	74.95	0.10	0.69	2.61	9.65	165.20	884.1	24:00:00
13/02/2022	0	0.65	26.22	1.47	74.38	0.10	0.68	2.34	9.49	160.96	879.3	21:42:50
14/02/2022	0	0.46	27.42	1.06	74.21	0.13	0.67	0.16	9.48	162.43	876.0	23:57:50
15/02/2022	0	0.28	26.85	1.27	73.33	0.12	0.68	1.52	9.62	162.92	881.1	23:26:50
16/02/2022	0	0.19	26.71	0.94	74.92	0.09	0.68	2.42	9.77	166.71	890.4	23:55:00
17/02/2022	0	0.88	24.77	1.22	75.68	0.13	0.72	2.49	9.97	167.94	890.0	24:00:00
18/02/2022	0	0.40	26.04	1.11	75.50	0.08	0.72	2.38	9.88	167.85	883.1	24:00:00
19/02/2022	0	0.37	23.23	1.18	76.39	0.08	0.71	2.31	9.87	167.17	886.6	24:00:00
20/02/2022	0	0.23	23.14	1.50	76.85	0.10	0.71	2.25	9.82	166.27	889.6	24:00:00
21/02/2022	0	0.27	21.66	1.47	74.62	0.12	0.71	1.75	9.72	161.09	890.2	18:58:30
22/02/2022	0	0.46	24.88	1.63	73.81	0.10	0.71	0.23	9.82	165.04	886.4	23:17:10
23/02/2022	0	0.33	24.43	1.29	72.72	0.12	0.70	0.15	9.74	165.06	889.0	24:00:00
24/02/2022	0	0.21	23.23	1.61	74.68	0.11	0.70	0.13	9.67	164.66	894.4	24:00:00
25/02/2022	0	0.30	26.20	1.15	70.77	0.12	0.67	0.11	9.50	164.14	878.9	24:00:00
26/02/2022	0	0.28	26.25	0.81	71.90	0.11	0.67	0.11	9.60	163.79	877.6	24:00:00
27/02/2022	0	0.24	27.89	0.81	75.54	0.09	0.68	0.12	9.69	164.12	876.7	24:00:00
28/02/2022	0	0.28	27.90	1.16	75.63	0.13	0.70	0.11	9.63	165.01	877.4	24:00:00
<b>Min</b>	<b>0</b>	<b>0.19</b>	<b>18.99</b>	<b>0.67</b>	<b>18.72</b>	<b>0.07</b>	<b>0.67</b>	<b>0.11</b>	<b>7.62</b>	<b>158.03</b>	<b>859.1</b>	
<b>Max</b>	<b>1</b>	<b>2.26</b>	<b>30.44</b>	<b>2.10</b>	<b>76.85</b>	<b>0.22</b>	<b>0.79</b>	<b>2.65</b>	<b>9.97</b>	<b>167.94</b>	<b>894.4</b>	
<b>Sr.</b>	<b>0</b>	<b>0.86</b>	<b>25.58</b>	<b>1.25</b>	<b>56.52</b>	<b>0.14</b>	<b>0.72</b>	<b>1.70</b>	<b>9.48</b>	<b>164.42</b>	<b>881.9</b>	<b>27d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>08:20:10</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>				