

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Grudzień 2023**

Jedn.	ANALIZATOR : gaz 11% O2									Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	O2 Sec	Temperatur	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>					
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>					
01/12/2023	0	0.57	28.73	2.59	15.45	0.32	0.23	1.52	17.83	11.94	164.91	873.5	23:55:00
02/12/2023	0	0.60	28.45	2.42	15.67	0.32	0.23	1.48	17.73	11.98	164.55	872.6	24:00:00
03/12/2023	0	0.77	27.03	2.40	16.98	0.31	0.28	1.55	12.83	12.20	165.06	875.4	22:46:20
04/12/2023	0	0.50	27.10	2.40	15.14	0.34	0.30	1.54	10.10	12.21	164.22	875.5	23:54:00
05/12/2023	0	0.27	22.21	2.18	15.98	0.41	0.23	1.43	10.29	12.04	159.45	879.1	17:29:20
06/12/2023	0	0.27	30.54	2.50	16.43	0.25	0.22	1.43	9.07	11.97	161.44	884.7	19:51:40
07/12/2023	0	0.71	28.55	4.92	18.60	0.28	0.79	1.97	10.23	11.94	164.96	883.1	23:59:40
08/12/2023	0	0.63	26.22	7.34	16.30	0.31	0.25	2.22	9.56	11.07	166.31	882.8	24:00:00
09/12/2023	0	0.61	23.89	8.85	15.85	0.22	0.25	2.22	9.86	11.09	166.53	883.1	24:00:00
10/12/2023	0	0.46	25.67	7.82	13.85	0.19	0.26	2.25	9.88	11.16	167.36	881.9	24:00:00
11/12/2023	0	0.32	22.86	6.45	15.78	0.16	0.25	2.26	10.77	11.17	168.78	880.0	23:59:30
12/12/2023	0	0.30	28.17	6.46	16.18	0.27	0.25	2.23	10.67	11.14	168.34	878.5	24:00:00
13/12/2023	0	0.60	21.69	6.87	14.36	0.33	0.23	2.07	11.20	11.17	167.11	878.6	24:00:00
14/12/2023	0	0.49	21.13	7.13	16.89	0.34	0.22	2.88	8.72	11.05	166.29	884.0	22:14:10
15/12/2023	0	0.43	18.30	6.32	16.57	0.29	0.21	3.06	6.76	10.85	166.19	883.8	24:00:00
16/12/2023	0	0.33	22.19	5.86	15.65	0.29	0.22	2.91	7.07	10.78	165.76	881.2	24:00:00
17/12/2023	0	0.34	32.27	5.97	16.20	0.29	0.22	2.91	10.01	10.84	167.05	872.0	24:00:00
18/12/2023	0	0.34	7.84	34.86	16.46	0.25	0.21	2.73	22.90	10.60	151.66	867.7	06:03:40
19/12/2023	0	0.37	0.07	23.17	20.68	0.48	0.20	3.21	15.76	10.66	150.40	884.1	07:13:40
20/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	10.82	151.34	PIEC O	00:01:50
21/12/2023	0	0.44	18.13	6.54	22.80	0.13	0.22	1.54	0.87	11.52	139.08	853.9	11:16:40
22/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.67	95.66	PIEC O	00:00:00
23/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.47	111.50	PIEC O	00:00:00
24/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.88	102.68	PIEC O	00:00:00
25/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.56	75.71	PIEC O	00:00:00
26/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.34	66.06	PIEC O	00:00:00
27/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.02	60.30	PIEC O	00:00:00
28/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	10.96	32.38	PIEC O	00:00:00
29/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.00	27.48	PIEC O	00:00:00
30/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.01	24.73	PIEC O	00:00:00
31/12/2023	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	11.02	27.43	PIEC O	00:00:00
<b>Min</b>	<b>0</b>	<b>0.27</b>	<b>0.07</b>	<b>2.18</b>	<b>13.85</b>	<b>0.13</b>	<b>0.20</b>	<b>1.43</b>	<b>0.87</b>	<b>10.60</b>	<b>24.73</b>	<b>853.9</b>	
<b>Max</b>	<b>0</b>	<b>0.77</b>	<b>32.27</b>	<b>34.86</b>	<b>22.80</b>	<b>0.48</b>	<b>0.79</b>	<b>3.21</b>	<b>22.90</b>	<b>12.21</b>	<b>168.78</b>	<b>884.7</b>	
<b>Sr.</b>	<b>0</b>	<b>0.47</b>	<b>23.05</b>	<b>7.65</b>	<b>16.59</b>	<b>0.29</b>	<b>0.26</b>	<b>2.17</b>	<b>11.11</b>	<b>11.33</b>	<b>130.02</b>	<b>877.8</b>	<b>17d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>					<b>10:45:30</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>					