

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Czerwiec 2023

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2	10	50	50	200	1	10	10	10				
PrA3g 1	60	200	100	400	4	20	30					
01/06/2023	0	0.64	29.91	2.23	137.49	0.20	0.23	1.00	10.37	165.36	881.3	21:55:10
02/06/2023	0	0.74	27.27	2.22	125.69	0.25	0.24	0.25	10.29	166.95	881.5	23:59:50
03/06/2023	0	0.72	28.71	2.20	138.68	0.23	0.25	0.21	10.16	167.48	878.4	24:00:00
04/06/2023	0	0.88	30.40	2.20	144.41	0.24	0.25	0.21	10.12	168.31	875.9	24:00:00
05/06/2023	0	0.78	28.63	2.84	127.31	0.36	0.37	0.25	11.90	168.32	875.5	23:28:30
06/06/2023	1	0.51	23.59	3.43	60.18	0.44	0.51	0.30	15.70	167.56	876.1	24:00:00
07/06/2023	1	0.52	27.80	3.31	63.57	0.45	0.51	0.25	16.08	165.50	871.2	19:14:20
08/06/2023	1	0.49	34.75	3.51	60.77	0.43	0.51	0.26	15.65	168.10	882.0	23:58:20
09/06/2023	1	0.66	35.29	4.19	58.79	0.46	0.45	0.26	15.70	167.91	877.6	23:14:50
10/06/2023	1	0.57	29.53	4.26	60.33	0.45	0.60	0.25	15.92	166.47	874.4	19:26:20
11/06/2023	1	0.53	36.35	5.86	55.39	0.45	0.54	6.25	15.98	165.31	870.6	20:51:40
12/06/2023	1	0.59	30.93	3.73	64.87	0.46	0.52	2.73	16.10	164.72	869.6	23:59:40
13/06/2023	1	0.61	33.28	4.34	59.50	0.46	0.48	1.81	15.93	165.94	881.2	24:00:00
14/06/2023	1	0.60	29.05	4.35	62.95	0.47	0.55	1.97	16.32	162.63	881.7	19:39:40
15/06/2023	1	0.53	30.51	4.63	60.58	0.43	0.57	1.43	16.00	164.92	881.2	22:57:00
16/06/2023	1	0.53	30.45	4.68	60.78	0.45	0.56	0.63	16.06	165.70	874.7	24:00:00
17/06/2023	1	0.55	28.72	4.05	62.39	0.44	1.66	0.52	15.99	165.57	873.5	23:53:50
18/06/2023	1	0.56	30.40	4.62	59.54	0.45	2.12	1.35	16.24	164.50	866.9	21:54:00
19/06/2023	1	0.52	31.68	5.22	62.85	0.45	0.44	1.82	16.26	166.23	863.2	20:57:50
20/06/2023	1	0.49	32.95	3.70	50.88	0.40	0.34	2.02	16.60	160.80	864.9	13:51:00
21/06/2023	1	0.40	26.24	4.21	36.17	0.31	0.24	0.68	13.37	165.86	869.4	22:51:10
22/06/2023	1	0.60	26.95	5.87	36.81	0.33	0.30	0.43	13.32	166.60	867.7	24:00:00
23/06/2023	1	0.56	27.19	2.34	40.71	0.34	0.38	0.36	13.15	166.92	886.9	24:00:00
24/06/2023	1	0.69	30.28	8.10	39.52	0.33	0.34	0.34	13.33	166.67	879.6	24:00:00
25/06/2023	1	0.62	31.26	11.38	37.99	0.30	0.30	0.33	13.36	166.74	871.1	24:00:00
26/06/2023	1	0.48	30.69	2.83	45.45	0.32	0.27	0.31	13.37	166.96	872.5	24:00:00
27/06/2023	1	0.66	30.40	2.13	52.97	0.30	0.29	0.31	13.36	166.30	871.6	24:00:00
28/06/2023	1	0.57	30.08	2.16	54.49	0.30	0.31	0.32	13.46	166.38	877.5	24:00:00
29/06/2023	1	0.49	30.06	3.16	49.93	0.30	0.27	0.31	13.40	167.46	883.4	24:00:00
30/06/2023	1	0.52	30.53	2.48	53.35	0.31	0.29	0.31	13.36	168.29	884.5	24:00:00
Min	0	0.40	23.59	2.13	36.17	0.20	0.23	0.21	10.12	160.80	863.2	
Max	1	0.88	36.35	11.38	144.41	0.47	2.12	6.25	16.60	168.32	886.9	
Sr.	1	0.59	30.13	4.01	67.48	0.37	0.49	0.92	14.23	166.22	875.5	28d
PrA3g 2	0	0	0	0	0	0	0	0				10:13:10
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:30				