

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Maj 2023**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>	<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>	<b>10</b>				
<b>PrA3g 1</b>	<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>					
01/05/2023	0	0.78	29.92	2.26	82.39	0.12	0.25	0.39	10.51	163.69	887.0	22:10:30
02/05/2023	0	0.62	31.40	2.25	78.29	0.12	0.25	0.16	10.51	162.59	885.5	24:00:00
03/05/2023	0	0.71	31.07	2.24	98.03	0.10	0.25	0.14	10.46	161.23	883.7	24:00:00
04/05/2023	0	0.76	30.27	2.22	112.60	0.11	0.25	0.13	10.33	162.50	890.1	24:00:00
05/05/2023	0	0.79	28.48	2.23	98.99	0.10	0.25	0.12	10.40	164.76	889.6	24:00:00
06/05/2023	0	0.73	28.53	2.24	101.54	0.11	0.25	0.13	10.43	165.20	887.3	23:59:50
07/05/2023	0	0.59	33.43	2.24	123.73	0.10	0.25	0.14	10.39	166.31	879.1	24:00:00
08/05/2023	0	0.53	33.63	2.22	134.50	0.13	0.25	0.13	10.25	165.43	879.8	24:00:00
09/05/2023	0	0.60	27.22	2.22	118.18	0.15	0.25	0.33	10.31	164.53	884.3	23:14:00
10/05/2023	0	0.48	28.80	2.23	107.62	0.17	0.25	0.17	10.37	164.63	878.0	23:59:10
11/05/2023	0	0.52	28.71	2.24	95.93	0.14	0.25	0.14	10.44	165.96	877.7	24:00:00
12/05/2023	0	0.65	28.43	2.23	130.22	0.09	0.25	0.13	10.26	166.65	889.7	24:00:00
13/05/2023	0	0.58	25.46	2.23	109.29	0.13	0.25	0.12	10.35	165.80	887.1	24:00:00
14/05/2023	0	0.75	33.45	2.24	132.90	0.15	0.25	0.12	10.33	168.27	879.2	24:00:00
15/05/2023	0	0.94	30.18	2.26	127.91	0.13	0.25	0.12	10.38	168.71	883.1	24:00:00
16/05/2023	0	0.71	31.10	2.24	135.71	0.14	0.25	0.12	10.28	169.12	884.0	24:00:00
17/05/2023	0	0.86	28.45	2.24	131.62	0.14	0.25	0.13	10.33	167.71	873.7	24:00:00
18/05/2023	0	1.01	28.85	2.21	138.70	0.22	0.25	0.13	10.20	169.19	876.7	24:00:00
19/05/2023	0	0.95	29.27	2.22	142.53	0.17	0.25	0.13	10.16	169.75	879.4	24:00:00
20/05/2023	0	0.82	30.20	2.21	143.78	0.16	0.25	0.23	10.40	161.57	873.9	18:55:20
21/05/2023	0	0.88	30.62	2.22	145.94	0.17	0.25	0.51	10.11	171.08	878.4	24:00:00
22/05/2023	0	0.89	29.48	2.22	145.09	0.20	0.25	0.17	10.07	172.37	885.3	24:00:00
23/05/2023	0	0.74	29.74	2.22	147.04	0.20	0.25	0.17	10.14	170.76	890.3	24:00:00
24/05/2023	0	0.86	29.09	2.22	147.00	0.16	0.24	0.15	10.20	169.97	886.3	24:00:00
25/05/2023	0	0.78	28.19	2.22	146.19	0.21	0.25	0.12	10.31	166.47	873.1	24:00:00
26/05/2023	0	0.78	28.18	2.21	146.11	0.19	0.24	0.12	10.08	167.41	871.9	24:00:00
27/05/2023	0	0.76	26.65	2.18	143.39	0.17	0.24	0.12	9.89	170.45	881.8	24:00:00
28/05/2023	0	0.56	31.19	2.24	94.13	0.23	0.24	0.12	11.37	164.33	866.2	19:06:40
29/05/2023	0	0.57	27.91	2.22	108.22	0.26	0.25	0.12	10.34	165.96	872.8	24:00:00
30/05/2023	0	0.90	29.65	2.21	138.62	0.22	0.25	0.13	10.18	167.52	883.3	24:00:00
31/05/2023	0	0.86	30.12	2.20	135.05	0.25	0.25	0.23	10.29	164.99	878.9	21:39:20
<b>Min</b>	<b>0</b>	<b>0.48</b>	<b>25.46</b>	<b>2.18</b>	<b>78.29</b>	<b>0.09</b>	<b>0.24</b>	<b>0.12</b>	<b>9.89</b>	<b>161.23</b>	<b>866.2</b>	
<b>Max</b>	<b>0</b>	<b>1.01</b>	<b>33.63</b>	<b>2.26</b>	<b>147.04</b>	<b>0.26</b>	<b>0.25</b>	<b>0.51</b>	<b>11.37</b>	<b>172.37</b>	<b>890.3</b>	
<b>Sr.</b>	<b>0</b>	<b>0.74</b>	<b>29.60</b>	<b>2.23</b>	<b>123.91</b>	<b>0.16</b>	<b>0.25</b>	<b>0.17</b>	<b>10.32</b>	<b>166.61</b>	<b>881.2</b>	<b>30d</b>
<b>PrA3g 2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>09:04:50</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>				