

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Czerwiec 2024**

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatu	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>8</b>	<b>40</b>	<b>50</b>	<b>180</b>	<b>1</b>	<b>10</b>	<b>5</b>	<b>15</b>	<b>20</b>				
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>						
01/06/2024	1	0.69	22.36	9.01	25.51	0.19	0.83	2.36	4.24	3.62	13.29	162.62	891.3	24:00:00
02/06/2024	1	1.12	25.95	9.60	24.99	0.19	0.83	2.23	4.55	3.35	13.37	161.03	879.1	23:32:10
03/06/2024	1	0.80	21.38	10.19	25.96	0.22	0.98	2.52	4.58	6.81	13.44	160.63	882.3	22:30:10
04/06/2024	1	0.97	23.07	9.67	25.49	0.23	0.72	2.29	4.54	3.51	13.41	161.13	882.0	24:00:00
05/06/2024	1	0.88	21.88	8.83	22.84	0.20	1.09	2.16	3.76	2.96	12.24	160.47	888.6	22:22:20
06/06/2024	1	0.90	24.03	10.04	25.72	0.19	1.02	2.18	3.90	3.97	13.36	162.82	888.4	23:58:40
07/06/2024	1	0.72	24.00	9.63	26.06	0.19	0.84	2.16	3.59	4.20	13.38	162.87	892.5	24:00:00
08/06/2024	1	0.63	22.95	9.23	25.62	0.21	0.95	2.16	4.04	3.91	13.36	162.68	885.6	24:00:00
09/06/2024	1	0.97	23.15	9.61	25.39	0.21	0.90	2.16	3.46	4.29	13.31	163.23	888.3	24:00:00
10/06/2024	1	1.11	23.24	9.73	25.57	0.19	0.84	2.16	3.64	5.62	13.27	162.74	887.1	24:00:00
11/06/2024	1	0.85	23.12	8.34	24.34	0.15	0.83	2.06	3.13	3.88	13.11	162.50	890.4	24:00:00
12/06/2024	0	0.39	23.14	4.01	21.58	0.08	0.38	1.86	2.63	3.06	12.92	161.55	887.2	24:00:00
13/06/2024	0	0.38	22.57	4.03	21.02	0.08	0.38	1.87	2.91	2.96	12.92	162.32	891.8	24:00:00
14/06/2024	0	0.44	22.87	4.01	21.94	0.08	0.38	2.45	2.54	3.16	12.90	160.51	888.8	21:43:20
15/06/2024	0	0.41	23.39	4.10	22.20	0.08	0.39	2.02	5.02	3.77	13.06	161.82	887.2	22:50:20
16/06/2024	0	0.39	21.08	5.92	21.11	0.08	0.37	2.09	2.54	3.59	13.00	154.97	891.3	20:26:30
17/06/2024	1	0.68	22.74	8.82	24.56	0.16	1.06	2.24	4.03	6.07	13.12	155.70	891.8	20:01:50
18/06/2024	1	1.01	22.91	9.70	24.69	0.20	2.10	2.17	4.69	4.36	13.23	161.46	887.9	24:00:00
19/06/2024	1	1.22	22.44	9.17	23.22	0.20	1.60	2.51	5.97	5.14	13.21	157.06	885.7	19:48:30
20/06/2024	1	1.02	20.54	10.20	23.02	0.19	2.00	2.06	3.82	4.03	13.26	155.46	881.8	20:26:20
21/06/2024	1	0.91	23.59	9.63	25.21	0.20	1.93	2.01	5.47	5.01	13.21	165.56	884.8	24:00:00
22/06/2024	1	1.23	19.25	10.23	23.12	0.20	1.88	2.16	5.81	5.45	13.19	162.90	875.2	22:23:10
23/06/2024	1	0.99	23.70	10.43	24.75	0.18	1.63	1.96	4.21	3.70	13.16	164.51	881.4	24:00:00
24/06/2024	1	0.88	22.96	9.91	25.05	0.17	1.88	1.90	3.99	6.72	13.17	164.23	886.8	24:00:00
25/06/2024	1	1.10	22.87	9.19	24.55	0.19	1.73	1.91	3.46	5.20	13.18	164.11	885.3	24:00:00
26/06/2024	1	0.97	23.53	9.48	25.06	0.20	2.11	1.94	5.00	5.58	13.18	165.35	881.0	24:00:00
27/06/2024	1	0.91	23.23	9.26	24.57	0.21	1.65	2.06	5.24	6.04	13.16	166.51	887.1	23:54:00
28/06/2024	1	1.00	22.64	10.04	24.16	0.22	1.69	2.36	6.90	5.18	13.23	163.30	882.0	21:03:00
29/06/2024	1	1.11	23.27	10.32	24.48	0.21	1.78	2.04	7.14	5.36	13.26	165.91	884.0	22:51:50
30/06/2024	1	1.08	15.65	11.04	23.79	0.20	1.85	2.02	5.29	5.19	13.19	160.77	868.2	20:17:50
<b>Min</b>	<b>0</b>	<b>0.38</b>	<b>15.65</b>	<b>4.01</b>	<b>21.02</b>	<b>0.08</b>	<b>0.37</b>	<b>1.86</b>	<b>2.54</b>	<b>2.96</b>	<b>12.24</b>	<b>154.97</b>	<b>868.2</b>	
<b>Max</b>	<b>1</b>	<b>1.23</b>	<b>25.95</b>	<b>11.04</b>	<b>26.06</b>	<b>0.23</b>	<b>2.11</b>	<b>2.52</b>	<b>7.14</b>	<b>6.81</b>	<b>13.44</b>	<b>166.51</b>	<b>892.5</b>	
<b>Sr.</b>	<b>1</b>	<b>0.86</b>	<b>22.58</b>	<b>8.78</b>	<b>24.19</b>	<b>0.18</b>	<b>1.22</b>	<b>2.14</b>	<b>4.34</b>	<b>4.52</b>	<b>13.17</b>	<b>161.89</b>	<b>885.5</b>	<b>28d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>16:10:00</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:30</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						