

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Marzec 2024**

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatu	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
<b>PrA3g 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>						
<b>PrA3g 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>						
01/03/2024	0	0.66	23.11	8.27	29.55	0.09	0.30	1.99	4.26	5.02	13.41	165.13	893.2	24:00:00
02/03/2024	0	0.52	24.33	8.60	30.09	0.09	0.27	1.93	4.45	5.89	13.44	164.68	885.4	24:00:00
03/03/2024	0	0.39	28.49	7.97	30.95	0.08	0.27	1.94	5.48	5.27	13.49	165.31	873.6	24:00:00
04/03/2024	0	0.41	28.26	7.92	29.47	0.09	0.30	1.91	5.29	4.02	13.21	152.14	867.4	07:07:10
05/03/2024	0	0.40	18.14	8.03	28.85	0.09	0.32	3.04	4.14	6.27	13.15	142.23	890.2	09:17:40
06/03/2024	0	0.34	30.54	7.82	28.61	0.08	0.29	2.09	4.67	8.30	13.32	163.18	891.4	24:00:00
07/03/2024	0	0.66	29.32	7.74	26.15	0.08	0.29	2.07	4.11	6.26	13.28	162.12	889.1	24:00:00
08/03/2024	1	1.95	23.99	14.15	30.03	0.27	2.90	2.45	5.45	6.05	13.70	161.01	890.4	24:00:00
09/03/2024	1	2.19	27.01	11.60	28.60	0.27	2.15	2.19	5.13	3.82	13.48	160.48	890.4	24:00:00
10/03/2024	1	2.74	28.49	10.30	28.34	0.27	1.98	2.11	4.87	3.16	13.18	161.98	889.7	24:00:00
11/03/2024	1	3.13	28.16	9.11	27.41	0.26	1.76	2.05	5.82	3.64	13.23	161.54	891.5	24:00:00
12/03/2024	1	2.69	24.28	8.91	27.58	0.27	1.86	2.33	6.17	3.33	13.25	159.46	884.1	22:17:40
13/03/2024	1	2.72	27.89	10.27	26.86	0.27	1.68	2.60	5.62	3.26	13.27	154.72	880.4	16:43:20
14/03/2024	1	2.73	28.07	11.38	27.46	0.29	2.18	2.21	5.91	4.09	13.32	160.15	882.6	24:00:00
15/03/2024	1	2.28	26.17	9.91	27.52	0.28	1.50	2.88	5.68	4.10	13.32	154.90	876.2	16:57:00
16/03/2024	1	3.12	28.94	10.05	28.00	0.31	2.29	3.32	5.66	3.92	13.33	159.78	881.8	19:39:00
17/03/2024	1	3.37	30.43	9.93	24.90	0.28	2.65	2.12	3.12	3.23	13.32	159.32	872.7	24:00:00
18/03/2024	1	1.86	20.77	9.01	24.52	0.21	2.16	2.04	3.07	6.81	13.31	155.00	860.0	23:59:50
19/03/2024	1	2.16	29.65	7.67	25.30	0.26	1.07	2.43	3.08	5.89	13.32	156.17	860.9	19:12:50
20/03/2024	1	1.97	27.17	9.20	29.40	0.25	0.81	2.24	3.33	4.95	13.20	160.35	884.5	24:00:00
21/03/2024	1	2.45	30.26	9.43	27.60	0.27	2.03	2.14	3.24	3.58	13.14	161.42	886.4	24:00:00
22/03/2024	1	1.99	22.25	10.00	27.22	0.24	2.17	2.64	3.16	3.55	13.19	152.46	883.1	12:26:30
23/03/2024	1	1.54	29.85	9.29	26.61	0.20	2.02	2.41	3.05	5.48	13.01	160.74	881.5	24:00:00
24/03/2024	1	2.65	28.13	10.01	24.90	0.28	2.16	1.97	3.53	3.08	12.99	159.95	880.0	24:00:00
25/03/2024	1	2.55	29.39	9.76	24.32	0.25	2.30	1.90	4.34	3.62	12.53	160.32	876.4	23:57:00
26/03/2024	1	2.06	29.23	8.99	25.43	0.24	1.65	2.01	3.75	3.26	12.89	161.52	885.9	24:00:00
27/03/2024	1	2.32	30.13	8.46	24.51	0.26	2.35	2.02	3.67	4.36	12.80	161.71	878.8	24:00:00
28/03/2024	1	2.68	29.08	8.56	24.46	0.27	2.24	2.02	3.57	4.19	12.78	162.12	883.6	24:00:00
29/03/2024	1	2.74	30.28	9.30	23.66	0.24	2.07	2.01	3.72	3.67	12.91	161.76	878.3	24:00:00
30/03/2024	1	2.23	22.07	9.12	24.41	0.23	1.69	2.50	4.38	4.49	12.91	159.39	874.3	19:31:20
31/03/2024	1	2.23	26.57	7.96	24.47	0.25	3.03	2.22	4.12	5.82	12.89	160.17	871.8	17:40:40
<b>Min</b>	<b>0</b>	<b>0.34</b>	<b>18.14</b>	<b>7.67</b>	<b>23.66</b>	<b>0.08</b>	<b>0.27</b>	<b>1.90</b>	<b>3.05</b>	<b>3.08</b>	<b>12.53</b>	<b>142.23</b>	<b>860.0</b>	
<b>Max</b>	<b>1</b>	<b>3.37</b>	<b>30.54</b>	<b>14.15</b>	<b>30.95</b>	<b>0.31</b>	<b>3.03</b>	<b>3.32</b>	<b>6.17</b>	<b>8.30</b>	<b>13.70</b>	<b>165.31</b>	<b>893.2</b>	
<b>Sr.</b>	<b>1</b>	<b>1.99</b>	<b>27.11</b>	<b>9.31</b>	<b>27.01</b>	<b>0.22</b>	<b>1.64</b>	<b>2.25</b>	<b>4.38</b>	<b>4.59</b>	<b>13.18</b>	<b>159.39</b>	<b>881.1</b>	<b>27d</b>
<b>PrA3g 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>						<b>16:50:00</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						