

MPWiK Krakow STUO

Raport Miesięczny

Raport miesięczny
Grudzień 2019

| Jedn. | ANALIZATOR : gaz 11% O2 | | | | | | | | Proces | | | |
|---------------|-------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|--------------|-----------------|
| | Select Analyzer | HCL | SO2 | CO30m | NOX | HF | COT | Pyl | O2 Sec | Temperature | T2S | PIEC |
| | | mg/Nm3 | mg/Nm3 | mg/Nm3 | mg/Nm3 | mg/Nm3 | mg/Nm3 | mg/Nm3 | % | degreC | degreC | hh:mm:ss |
| Próg 2 | | 10 | 50 | 50 | 200 | 1 | 10 | 10 | | | | |
| Próg 1 | | 60 | 200 | 100 | 400 | 4 | 20 | 30 | | | | |
| 01/12/2019 | 0 | 0.32 | 27.86 | 4.57 | 46.97 | 0.23 | 1.24 | 0.10 | 13.12 | 168.64 | 870.2 | 24:00:00 |
| 02/12/2019 | 0 | 0.32 | 29.34 | 2.52 | 44.61 | 0.29 | 1.01 | 0.05 | 13.12 | 168.61 | 865.0 | 24:00:00 |
| 03/12/2019 | 0 | 0.33 | 28.57 | 2.78 | 46.17 | 0.30 | 1.28 | 0.02 | 13.11 | 168.79 | 865.1 | 24:00:00 |
| 04/12/2019 | 0 | 0.33 | 28.19 | 2.57 | 48.45 | 0.28 | 1.60 | 0.02 | 13.14 | 168.52 | 864.2 | 24:00:00 |
| 05/12/2019 | 0 | 0.34 | 28.06 | 2.32 | 48.65 | 0.30 | 1.24 | 0.05 | 13.08 | 168.14 | 860.2 | 24:00:00 |
| 06/12/2019 | 0 | 0.32 | 27.95 | 2.22 | 47.14 | 0.35 | 1.04 | 0.07 | 13.05 | 168.33 | 862.0 | 24:00:00 |
| 07/12/2019 | 0 | 0.32 | 28.39 | 2.60 | 45.34 | 0.32 | 0.79 | 0.04 | 13.01 | 169.03 | 864.7 | 24:00:00 |
| 08/12/2019 | 0 | 0.31 | 27.15 | 3.00 | 46.06 | 0.29 | 1.29 | 0.02 | 12.88 | 171.20 | 866.3 | 24:00:00 |
| 09/12/2019 | 0 | 0.31 | 20.59 | 2.73 | 46.71 | 0.29 | 1.02 | 0.03 | 12.83 | 172.16 | 863.7 | 24:00:00 |
| 10/12/2019 | 0 | 0.33 | 25.17 | 2.39 | 48.86 | 0.35 | 1.23 | 0.34 | 13.11 | 171.69 | 862.1 | 22:10:40 |
| 11/12/2019 | 0 | 0.21 | 25.95 | 3.02 | 46.50 | 0.39 | 1.52 | 1.94 | 13.34 | 169.21 | 860.2 | 23:26:50 |
| 12/12/2019 | 0 | 0.30 | 29.34 | 4.50 | 50.73 | 0.41 | 1.18 | 4.62 | 13.91 | 165.06 | 863.8 | 21:15:10 |
| 13/12/2019 | 0 | 0.36 | 27.65 | 3.04 | 53.33 | 0.43 | 0.99 | 4.21 | 13.61 | 168.79 | 863.5 | 24:00:00 |
| 14/12/2019 | 0 | 0.35 | 24.68 | 2.57 | 53.99 | 0.42 | 0.89 | 3.98 | 13.60 | 169.91 | 861.1 | 24:00:00 |
| 15/12/2019 | 0 | 0.37 | 29.27 | 2.93 | 55.39 | 0.41 | 1.29 | 3.85 | 13.73 | 169.53 | 862.5 | 24:00:00 |
| 16/12/2019 | 0 | 0.38 | 30.07 | 2.79 | 56.21 | 0.42 | 1.69 | 4.20 | 14.81 | 165.01 | 862.4 | 17:30:50 |
| 17/12/2019 | 0 | 0.37 | 29.87 | 3.72 | 54.51 | 0.43 | 1.03 | 3.24 | 13.72 | 168.35 | 863.3 | 24:00:00 |
| 18/12/2019 | 0 | 0.37 | 29.71 | 3.82 | 56.55 | 0.43 | 1.15 | 5.40 | 14.03 | 167.21 | 865.1 | 19:30:50 |
| 19/12/2019 | 0 | 0.37 | 30.32 | 3.37 | 55.30 | 0.42 | 1.81 | 3.23 | 14.61 | 159.32 | 866.1 | 20:26:10 |
| 20/12/2019 | 0 | 0.37 | 29.12 | 4.42 | 55.62 | 0.42 | 1.54 | 0.09 | 13.62 | 168.64 | 871.3 | 24:00:00 |
| 21/12/2019 | 0 | 0.36 | 27.88 | 4.87 | 55.88 | 0.42 | 3.22 | 0.01 | 13.56 | 169.06 | 872.9 | 24:00:00 |
| 22/12/2019 | 0 | 0.36 | 27.05 | 4.52 | 55.40 | 0.41 | 3.05 | 0.01 | 13.64 | 169.83 | 871.0 | 24:00:00 |
| 23/12/2019 | 0 | 0.37 | 27.80 | 3.52 | 53.69 | 0.42 | 2.36 | 0.01 | 13.64 | 169.24 | 867.3 | 24:00:00 |
| 24/12/2019 | 0 | 0.37 | 30.40 | 4.11 | 55.08 | 0.43 | 1.74 | 0.00 | 13.74 | 169.16 | 868.8 | 24:00:00 |
| 25/12/2019 | 0 | 0.37 | 29.38 | 3.19 | 55.33 | 0.41 | 1.69 | 0.00 | 13.81 | 169.17 | 869.6 | 24:00:00 |
| 26/12/2019 | 0 | 0.37 | 31.23 | 3.33 | 56.79 | 0.42 | 1.07 | 0.01 | 13.83 | 169.50 | 870.1 | 24:00:00 |
| 27/12/2019 | 0 | 0.39 | 27.79 | 3.02 | 55.25 | 0.42 | 1.38 | 0.01 | 14.23 | 166.36 | 861.8 | 24:00:00 |
| 28/12/2019 | 0 | 0.40 | 27.81 | 2.82 | 55.12 | 0.41 | 1.61 | 0.01 | 14.46 | 164.19 | 860.5 | 23:47:10 |
| 29/12/2019 | 0 | 0.39 | 31.69 | 3.01 | 57.45 | 0.44 | 2.02 | 0.03 | 15.00 | 162.29 | 863.0 | 19:11:30 |
| 30/12/2019 | 0 | 0.38 | 27.59 | 3.04 | 62.77 | 0.35 | 1.04 | 0.03 | 14.02 | 165.31 | 864.4 | 22:44:10 |
| 31/12/2019 | 0 | 0.37 | 29.51 | 3.19 | 57.94 | 0.38 | 1.09 | 0.01 | 13.74 | 167.90 | 866.8 | 24:00:00 |
| Min | 0 | 0.21 | 20.59 | 2.22 | 44.61 | 0.23 | 0.79 | 0.00 | 12.83 | 159.32 | 860.2 | |
| Max | 0 | 0.40 | 31.69 | 4.87 | 62.77 | 0.44 | 3.22 | 5.40 | 15.00 | 172.16 | 872.9 | |
| Sr. | 0 | 0.35 | 28.24 | 3.24 | 52.51 | 0.38 | 1.45 | 1.15 | 13.65 | 168.00 | 865.1 | 29d |
| Próg 2 | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | 22:03:20 |
| Próg 1 | | 00:00 | 00:00 | 00:00 | 00:00 | 00:00 | 00:00 | 01:30 | | | | |