

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Lipiec 2023

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		10	50	50	200	1	10	10				
PrA3g 1		60	200	100	400	4	20	30				
01/07/2023	1	0.40	30.53	2.91	52.13	0.32	0.26	0.29	13.28	167.87	878.5	24:00:00
02/07/2023	1	0.45	29.69	2.68	53.66	0.31	0.26	0.30	13.31	168.75	877.8	24:00:00
03/07/2023	1	0.49	30.04	3.13	51.17	0.31	0.31	0.30	13.78	166.24	874.7	20:35:20
04/07/2023	1	0.48	30.46	3.28	50.73	0.33	0.31	0.44	14.06	160.06	882.4	18:06:10
05/07/2023	1	0.50	30.53	3.03	50.00	0.34	0.31	1.03	13.61	168.17	871.5	24:00:00
06/07/2023	1	0.43	30.21	4.36	48.50	0.31	0.28	0.36	13.56	167.74	871.1	24:00:00
07/07/2023	1	0.40	28.38	3.64	47.97	0.29	0.32	0.31	13.62	167.92	869.1	24:00:00
08/07/2023	1	0.53	28.22	2.99	48.21	0.31	0.33	1.87	14.01	162.74	878.8	20:28:40
09/07/2023	1	0.61	31.46	12.80	46.50	0.32	0.31	0.53	13.63	168.12	869.8	24:00:00
10/07/2023	1	0.53	30.65	6.46	48.40	0.30	0.29	0.37	13.54	168.20	877.5	24:00:00
11/07/2023	1	0.65	31.08	8.53	47.35	0.29	0.27	0.28	13.58	167.91	872.2	24:00:00
12/07/2023	1	0.52	31.16	8.01	46.59	0.31	0.32	0.52	13.69	165.80	872.9	21:19:30
13/07/2023	1	0.51	28.85	4.70	47.24	0.30	0.31	1.50	13.61	165.67	883.8	22:30:10
14/07/2023	1	0.50	26.53	3.56	49.40	0.30	0.28	0.57	13.71	166.23	877.8	23:56:20
15/07/2023	1	0.56	25.35	2.95	51.18	0.31	0.28	0.49	13.62	168.45	870.7	23:59:50
16/07/2023	1	0.73	27.50	3.54	47.13	0.30	0.35	0.76	14.15	163.76	858.9	18:19:50
17/07/2023	1	0.71	26.26	2.68	50.63	0.29	0.33	0.87	13.90	165.07	859.1	24:00:00
18/07/2023	1	0.68	28.96	3.86	48.01	0.29	0.31	3.82	15.01	158.75	858.3	12:44:50
19/07/2023	1	0.61	29.89	4.73	47.49	0.30	0.30	1.77	13.64	168.06	862.9	23:59:40
20/07/2023	1	0.55	29.68	4.16	46.70	0.30	0.30	2.32	13.90	166.83	872.3	24:00:00
21/07/2023	1	0.46	28.04	4.66	48.67	0.31	0.36	2.98	14.26	158.57	876.7	18:34:10
22/07/2023	1	0.61	26.54	8.16	46.00	0.31	0.32	2.41	13.85	166.80	872.3	24:00:00
23/07/2023	1	0.57	26.09	9.92	47.22	0.30	0.31	2.33	13.87	167.11	857.8	23:54:30
24/07/2023	1	0.68	26.51	3.08	49.57	0.30	0.36	2.30	13.91	166.80	859.0	24:00:00
25/07/2023	1	0.64	28.85	4.44	46.38	0.30	0.31	2.28	13.78	165.96	862.0	24:00:00
26/07/2023	1	0.52	28.12	3.07	49.46	0.29	0.33	2.27	13.80	165.54	863.5	24:00:00
27/07/2023	1	0.56	29.49	3.46	47.71	0.30	0.32	2.29	13.80	166.35	865.2	24:00:00
28/07/2023	1	0.47	25.43	4.49	44.82	0.29	0.30	3.39	13.79	167.28	872.5	23:57:20
29/07/2023	1	0.64	23.63	3.61	47.67	0.30	0.32	4.32	13.79	167.77	868.2	23:44:20
30/07/2023	1	0.61	22.10	2.45	50.84	0.31	0.32	5.51	14.72	160.00	861.9	15:31:20
31/07/2023	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	16.69	119.54	PIEC O	00:00:00
Min	1	0.40	22.10	2.45	44.82	0.29	0.26	0.28	13.28	119.54	857.8	
Max	1	0.73	31.46	12.80	53.66	0.34	0.36	5.51	16.69	168.75	883.8	
Sr.	1	0.55	28.34	4.64	48.58	0.30	0.31	1.63	13.92	164.32	870.0	27d
PrA3g 2		0	0	0	0	0	0	0				23:42:00
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00				