

## MPWiK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Luty 2020**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>Próg 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>Próg 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/02/2020	0	0.37	28.79	3.78	51.96	0.37	1.08	1.93	13.67	165.86	867.2	23:37:00
02/02/2020	0	0.36	29.44	3.17	50.97	0.38	1.07	1.95	13.62	166.77	867.6	24:00:00
03/02/2020	0	0.37	26.64	4.47	51.31	0.38	1.08	1.94	13.65	168.59	871.6	24:00:00
04/02/2020	0	0.36	22.66	3.14	49.57	0.39	1.08	1.89	13.58	168.16	865.4	24:00:00
05/02/2020	0	0.35	25.07	3.25	49.21	0.38	1.19	1.88	13.75	167.73	868.3	23:54:10
06/02/2020	0	0.38	23.36	3.38	52.34	0.32	1.35	2.00	14.35	164.33	865.7	20:40:20
07/02/2020	0	0.38	26.15	3.50	51.66	0.31	1.13	1.92	13.79	166.81	863.5	23:59:50
08/02/2020	0	0.38	25.13	3.90	51.47	0.31	1.11	1.88	13.78	166.23	870.5	23:59:50
09/02/2020	0	0.35	22.92	2.99	51.58	0.33	1.33	1.85	13.80	167.05	864.4	24:00:00
10/02/2020	0	0.36	24.52	3.52	50.92	0.32	1.06	1.82	13.57	167.52	865.9	24:00:00
11/02/2020	0	0.36	26.08	4.21	52.13	0.32	1.06	1.79	13.56	168.01	872.9	24:00:00
12/02/2020	0	0.37	27.79	3.69	50.87	0.30	1.09	1.81	13.74	167.03	869.7	24:00:00
13/02/2020	0	0.37	28.03	3.21	50.37	0.32	1.10	1.83	13.80	167.46	867.9	24:00:00
14/02/2020	0	0.38	28.78	2.68	49.63	0.31	1.11	1.81	13.80	167.45	865.8	24:00:00
15/02/2020	0	0.38	30.88	4.21	49.83	0.31	1.11	1.78	13.85	167.79	871.5	24:00:00
16/02/2020	0	0.38	30.01	3.73	48.26	0.32	1.12	1.79	13.82	167.11	869.8	24:00:00
17/02/2020	0	0.37	28.23	5.03	48.70	0.31	1.39	3.67	14.34	161.59	870.9	15:39:10
18/02/2020	0	0.38	26.96	3.76	49.45	0.32	1.31	5.65	14.26	165.05	869.8	21:30:50
19/02/2020	0	0.38	25.06	4.14	49.09	0.32	1.09	4.88	13.81	167.16	864.6	24:00:00
20/02/2020	0	0.38	29.04	4.24	48.77	0.32	1.14	4.64	13.87	167.55	865.9	24:00:00
21/02/2020	0	0.38	27.57	4.69	48.99	0.32	1.12	4.60	13.87	167.25	865.0	24:00:00
22/02/2020	0	0.39	30.55	4.07	49.84	0.33	1.15	4.54	13.90	166.51	865.8	24:00:00
23/02/2020	0	0.37	30.65	4.10	49.16	0.32	1.10	4.27	13.71	167.03	874.3	23:59:50
24/02/2020	0	0.37	30.05	2.81	48.34	0.31	1.43	5.06	14.09	166.35	863.5	20:00:50
25/02/2020	0	0.37	29.16	3.46	48.31	0.31	1.09	5.95	13.63	167.09	866.7	23:37:50
26/02/2020	0	0.36	29.51	3.82	48.93	0.30	1.13	5.54	13.72	167.68	872.0	23:02:40
27/02/2020	0	0.38	25.91	5.24	49.44	0.32	1.15	5.57	13.77	166.87	871.7	24:00:00
28/02/2020	0	0.37	29.48	3.23	47.88	0.30	1.12	5.28	13.68	167.78	872.5	23:57:50
29/02/2020	0	0.37	28.68	4.00	47.08	0.31	1.35	5.19	14.22	162.46	868.1	20:26:40
<b>Min</b>	<b>0</b>	<b>0.35</b>	<b>22.66</b>	<b>2.68</b>	<b>47.08</b>	<b>0.30</b>	<b>1.06</b>	<b>1.78</b>	<b>13.56</b>	<b>161.59</b>	<b>863.5</b>	
<b>Max</b>	<b>0</b>	<b>0.39</b>	<b>30.88</b>	<b>5.24</b>	<b>52.34</b>	<b>0.39</b>	<b>1.43</b>	<b>5.95</b>	<b>14.35</b>	<b>168.59</b>	<b>874.3</b>	
<b>Sr.</b>	<b>0</b>	<b>0.37</b>	<b>27.49</b>	<b>3.77</b>	<b>49.86</b>	<b>0.33</b>	<b>1.16</b>	<b>3.27</b>	<b>13.83</b>	<b>166.70</b>	<b>868.2</b>	<b>28d</b>
<b>Próg 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				<b>00:26:50</b>
<b>Próg 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>				