

## MPWiK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Październik 2020**

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
<b>Próg 2</b>		<b>10</b>	<b>50</b>	<b>50</b>	<b>200</b>	<b>1</b>	<b>10</b>	<b>10</b>				
<b>Próg 1</b>		<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>				
01/10/2020	1	0.30	26.45	0.35	69.19	0.36	0.35	3.46	11.52	171.31	892.7	24:00:00
02/10/2020	1	0.30	32.63	0.36	87.48	0.40	0.81	3.44	11.56	170.30	877.6	24:00:00
03/10/2020	1	0.30	24.94	0.35	83.13	0.37	0.52	3.46	11.46	171.38	885.9	24:00:00
04/10/2020	1	0.31	23.21	0.35	71.57	0.36	0.44	3.41	11.63	170.28	886.2	24:00:00
05/10/2020	1	0.31	23.14	0.35	69.24	0.36	0.41	3.26	11.66	170.51	890.2	24:00:00
06/10/2020	1	0.31	25.14	0.36	65.77	0.35	0.41	3.26	11.79	171.35	889.6	24:00:00
07/10/2020	1	0.31	22.76	0.36	59.12	0.34	0.37	3.23	11.96	169.79	892.8	24:00:00
08/10/2020	1	0.32	24.43	0.36	59.69	0.33	0.35	3.22	12.12	169.12	891.8	24:00:00
09/10/2020	1	0.31	24.33	0.36	60.76	0.35	0.36	3.11	11.89	171.85	894.3	24:00:00
10/10/2020	1	0.30	29.60	0.35	81.99	0.34	0.45	2.94	11.54	172.72	889.4	24:00:00
11/10/2020	1	0.31	23.57	0.36	61.38	0.32	0.39	2.96	11.83	170.71	891.7	23:55:20
12/10/2020	1	0.31	25.13	0.35	63.97	0.31	0.37	2.91	11.65	170.93	893.2	24:00:00
13/10/2020	1	1.01	26.60	2.15	78.43	0.53	0.78	3.03	12.12	170.72	894.2	24:00:00
14/10/2020	0	0.35	23.77	10.18	99.59	0.29	0.93	2.94	13.63	169.16	892.2	24:00:00
15/10/2020	0	0.34	23.41	11.92	104.08	0.28	0.96	2.94	13.74	169.46	888.4	24:00:00
16/10/2020	0	0.38	30.60	12.80	109.88	0.26	0.98	2.94	13.85	172.57	893.7	23:56:20
17/10/2020	0	0.39	32.26	17.13	98.23	0.27	0.97	2.90	13.80	172.81	895.9	24:00:00
18/10/2020	0	0.49	33.52	13.56	90.50	0.29	0.92	2.72	13.57	172.44	897.3	24:00:00
19/10/2020	0	0.44	36.26	14.71	103.54	0.33	0.92	3.75	13.61	169.33	896.1	23:01:50
20/10/2020	0	0.46	28.83	11.31	115.34	0.27	0.97	4.26	12.76	122.39	891.2	08:52:30
21/10/2020	0	0.80	22.10	10.01	98.78	0.37	0.89	<b>15.24</b>	12.39	96.31	874.6	06:29:50
22/10/2020	0	0.44	31.02	10.19	110.17	0.36	0.88	5.37	13.43	169.44	883.8	24:00:00
23/10/2020	1	0.55	35.26	7.54	96.84	0.34	0.74	5.88	15.63	139.40	888.5	13:57:20
24/10/2020	1	0.71	26.85	4.22	86.04	0.34	0.65	5.20	12.36	167.81	890.5	24:00:00
25/10/2020	1	1.10	21.83	0.81	71.70	0.32	0.62	4.54	11.36	165.94	880.3	1d 01:00:00
26/10/2020	1	0.50	27.55	0.55	77.33	0.30	0.71	3.89	17.60	155.50	871.3	08:38:20
27/10/2020	1	0.54	36.61	0.46	65.63	0.31	0.70	4.12	13.66	167.24	874.1	24:00:00
28/10/2020	0	0.40	32.35	11.90	106.18	0.25	0.92	4.78	13.54	168.34	885.3	24:00:00
29/10/2020	0	0.34	31.73	10.62	100.17	0.29	0.91	4.59	13.54	169.01	887.4	24:00:00
30/10/2020	0	0.67	32.41	7.00	94.08	0.31	0.82	8.23	13.81	165.14	882.0	23:09:30
31/10/2020	0	0.37	28.61	9.04	111.04	0.34	0.94	4.68	13.59	168.14	892.1	24:00:00
<b>Min</b>	<b>0</b>	<b>0.30</b>	<b>21.83</b>	<b>0.35</b>	<b>59.12</b>	<b>0.25</b>	<b>0.35</b>	<b>2.72</b>	<b>11.36</b>	<b>96.31</b>	<b>871.3</b>	
<b>Max</b>	<b>1</b>	<b>1.10</b>	<b>36.61</b>	<b>17.13</b>	<b>115.34</b>	<b>0.53</b>	<b>0.98</b>	<b>15.24</b>	<b>17.60</b>	<b>172.81</b>	<b>897.3</b>	
<b>Sr.</b>	<b>1</b>	<b>0.45</b>	<b>27.96</b>	<b>5.50</b>	<b>85.51</b>	<b>0.33</b>	<b>0.69</b>	<b>4.21</b>	<b>12.86</b>	<b>164.56</b>	<b>888.2</b>	<b>28d</b>
<b>Próg 2</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>				<b>13:01:00</b>
<b>Próg 1</b>		<b>00:00</b>	<b>00:30</b>	<b>00:00</b>	<b>00:00</b>	<b>01:00</b>	<b>00:00</b>	<b>05:00</b>				