

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Kwiecień 2023

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2	10	50	50	200	1	10	10	10				
PrA3g 1	60	200	100	400	4	20	30					
01/04/2023	0	0.85	20.88	2.31	74.32	0.09	0.25	0.26	10.61	164.53	890.3	24:00:00
02/04/2023	0	1.03	26.07	2.27	107.70	0.09	0.25	0.19	10.45	165.54	890.4	24:00:00
03/04/2023	0	0.77	25.60	2.23	104.56	0.07	0.25	0.15	10.34	163.24	888.7	24:00:00
04/04/2023	0	0.69	23.81	2.22	102.17	0.06	0.25	0.15	10.31	164.33	889.7	22:35:40
05/04/2023	0	0.79	28.57	2.20	118.19	0.09	0.24	0.79	10.56	156.79	895.6	14:31:40
06/04/2023	0	0.91	17.78	2.22	73.38	0.07	0.24	0.45	10.68	152.40	894.9	13:22:30
07/04/2023	0	0.92	25.30	2.24	89.33	0.03	0.25	0.19	10.42	163.17	894.1	24:00:00
08/04/2023	0	0.80	24.48	2.23	74.50	0.09	0.25	0.15	10.41	160.88	895.9	24:00:00
09/04/2023	0	0.98	27.93	2.26	90.32	0.09	0.25	0.69	10.48	161.47	884.4	22:52:10
10/04/2023	0	0.80	26.39	2.26	97.91	0.07	0.25	0.32	10.44	161.14	887.4	22:35:40
11/04/2023	0	0.88	23.47	2.25	78.07	0.10	0.25	0.31	10.53	162.35	889.3	22:50:30
12/04/2023	0	0.76	26.39	2.26	71.33	0.13	0.25	0.48	10.63	160.34	887.3	20:16:30
13/04/2023	0	0.60	27.59	2.33	54.58	0.14	0.26	0.39	10.65	162.18	891.8	21:49:00
14/04/2023	0	0.65	24.94	2.28	62.41	0.13	0.26	0.19	10.63	165.45	889.3	24:00:00
15/04/2023	0	0.89	21.11	2.28	65.56	0.11	0.26	0.16	10.59	164.86	889.3	24:00:00
16/04/2023	0	0.92	25.89	2.25	107.38	0.12	0.25	0.16	10.44	165.53	887.4	24:00:00
17/04/2023	0	0.91	25.93	2.26	98.60	0.14	0.25	0.14	10.47	162.95	886.7	24:00:00
18/04/2023	0	0.78	22.78	2.25	113.02	0.11	0.25	0.38	10.45	161.32	891.0	22:01:00
19/04/2023	0	0.74	20.41	2.25	87.82	0.15	0.25	0.17	10.48	164.39	888.6	23:58:30
20/04/2023	0	0.69	23.05	2.25	80.47	0.11	0.25	0.14	10.44	166.30	893.8	24:00:00
21/04/2023	0	0.89	26.59	2.27	55.07	0.11	0.25	0.14	10.56	166.17	882.8	24:00:00
22/04/2023	0	0.73	23.47	2.26	82.51	0.09	0.25	0.13	10.52	166.37	891.0	23:11:30
23/04/2023	0	0.63	18.34	2.29	53.31	0.12	0.25	0.13	10.80	159.01	885.1	13:08:50
24/04/2023	0	0.82	26.37	2.27	85.08	0.10	0.25	0.13	10.46	167.50	892.0	24:00:00
25/04/2023	0	0.64	29.11	2.28	72.77	0.10	0.25	0.13	10.59	165.36	891.3	23:05:10
26/04/2023	0	0.98	27.76	2.25	105.88	0.12	0.24	0.13	10.40	166.88	895.5	24:00:00
27/04/2023	0	0.79	23.25	2.22	108.22	0.10	0.24	0.12	10.31	166.82	897.4	24:00:00
28/04/2023	0	0.91	26.27	2.21	131.61	0.07	0.25	0.12	10.17	168.91	899.6	24:00:00
29/04/2023	0	1.00	26.82	2.23	139.42	0.06	0.25	0.12	10.21	170.25	893.7	23:41:10
30/04/2023	0	0.91	31.43	2.23	143.84	0.05	0.25	0.12	10.21	168.42	887.8	23:11:30
Min	0	0.60	17.78	2.20	53.31	0.03	0.24	0.12	10.17	152.40	882.8	
Max	0	1.03	31.43	2.33	143.84	0.15	0.26	0.79	10.80	170.25	899.6	
Sr.	0	0.82	24.93	2.25	90.98	0.10	0.25	0.24	10.47	163.83	890.7	28d
PrA3g 2	0	0	0	0	0	0	0	0				01:11:20
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00				