

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Marzec 2021

ANALIZATOR : gaz 11% O2										Proces		PIEC	
Select	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature T2S		Temperature T2S	PIEC	
Analyzer									%	degreC	degreC	hh:mm:ss	
Jedn. _	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss	
PrA3g 2	10	50	50	200	1	10	10						
PrA3g 1	60	200	100	400	4	20	30						
01/03/2021	1	0.59	28.82	0.34	88.26	0.29	1.01	3.24	11.59	169.99	877.0	24:00:00	
02/03/2021	1	0.64	29.23	0.34	86.23	0.28	1.03	3.31	11.49	169.82	876.4	24:00:00	
03/03/2021	1	0.68	26.91	0.34	82.12	0.29	0.93	3.35	11.34	170.60	879.6	24:00:00	
04/03/2021	1	0.89	29.43	0.34	61.00	0.20	0.89	3.70	11.44	171.07	877.5	24:00:00	
05/03/2021	1	1.28	27.20	0.34	59.61	0.22	0.94	5.92	12.96	160.36	877.4	13:52:50	
06/03/2021	1	0.97	32.59	0.33	61.11	0.24	0.93	4.57	12.46	160.65	871.2	17:26:30	
07/03/2021	1	0.89	31.75	0.36	62.07	0.26	0.71	8.52	12.05	164.60	865.3	22:51:50	
08/03/2021	1	0.68	30.86	0.35	60.22	0.24	0.86	5.08	12.03	164.45	870.0	21:48:20	
09/03/2021	1	0.82	30.48	0.33	55.53	0.21	0.99	4.53	11.37	166.64	874.7	24:00:00	
10/03/2021	1	0.69	27.97	0.36	56.79	0.24	0.87	3.98	11.25	166.71	880.4	24:00:00	
11/03/2021	1	0.51	32.13	0.32	57.84	0.23	1.05	3.86	14.71	157.98	878.9	11:16:30	
12/03/2021	1	0.64	32.30	0.33	57.66	0.21	1.05	4.54	11.07	168.29	873.1	24:00:00	
13/03/2021	1	0.84	30.56	0.33	58.72	0.19	0.88	3.85	11.17	168.49	879.2	24:00:00	
14/03/2021	1	0.91	27.39	0.33	60.14	0.20	0.69	3.43	11.26	168.64	879.1	24:00:00	
15/03/2021	1	0.51	30.66	0.33	58.39	0.19	0.96	3.25	11.10	169.29	874.9	24:00:00	
16/03/2021	1	0.56	30.75	0.33	57.59	0.16	0.91	5.42	11.21	169.75	875.7	22:35:00	
17/03/2021	1	0.71	27.90	0.33	60.51	0.14	0.94	7.74	13.35	160.79	880.9	15:22:30	
18/03/2021	1	0.75	26.53	0.33	63.46	0.16	0.66	5.99	11.33	167.56	890.5	24:00:00	
19/03/2021	1	0.53	29.91	0.34	61.40	0.16	0.71	3.79	11.18	167.78	889.7	24:00:00	
20/03/2021	1	0.57	28.00	0.34	57.02	0.17	0.72	3.50	11.14	168.50	894.0	24:00:00	
21/03/2021	1	0.74	28.20	0.34	55.59	0.19	0.56	3.46	11.15	168.31	891.8	24:00:00	
22/03/2021	1	0.80	26.58	0.33	57.59	0.27	0.67	3.34	11.27	168.66	888.8	23:55:00	
23/03/2021	1	0.81	25.16	0.33	57.88	0.29	0.59	3.40	11.36	167.94	885.7	24:00:00	
24/03/2021	1	0.95	26.62	0.33	66.09	0.29	0.69	3.42	11.30	168.92	886.2	24:00:00	
25/03/2021	1	0.71	27.08	0.33	68.47	0.32	0.67	3.54	11.17	169.18	887.2	23:46:30	
26/03/2021	1	0.80	25.62	1.02	73.29	0.33	0.60	3.98	11.64	168.27	892.4	19:19:20	
27/03/2021	1	0.76	21.27	1.55	61.27	0.31	0.59	2.80	10.79	167.78	884.2	24:00:00	
28/03/2021	1	0.80	20.88	0.31	74.17	0.27	0.53	0.65	10.61	169.35	891.3	23:00:00	
29/03/2021	1	0.62	26.73	0.31	80.44	0.29	0.73	0.40	10.54	169.09	880.1	24:00:00	
30/03/2021	1	0.62	29.43	0.31	94.50	0.30	0.74	0.36	10.43	169.50	880.8	24:00:00	
31/03/2021	1	0.40	32.05	1.51	96.93	0.28	1.15	0.29	10.50	170.63	873.6	24:00:00	
Min	1	0.40	20.88	0.31	55.53	0.14	0.53	0.29	10.43	157.98	865.3		
Max	1	1.28	32.59	1.55	96.93	0.33	1.15	8.52	14.71	171.07	894.0		
Sr.	1	0.73	28.42	0.43	66.19	0.24	0.81	3.78	11.49	167.41	880.9	28d	
PrA3g 2	0	0	0	0	0	0	0	0				23:14:20	
PrA3g 1	00:00	00:00	00:00	00:00	00:00	00:00	00:00	00:30					

Zmiana czasu:
praca pieca
29d 0h 14:20

Z-ca KIEROWNIKA
Stacji Termicznej Butilizacji Usadów

Grzegorz Wojas