

MPWiK Krakow STUO

Raport Miesięczny

Raport miesięczny
Marzec 2020

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
Próg 2		10	50	50	200	1	10	10				
Próg 1		60	200	100	400	4	20	30				
01/03/2020	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	16.61	153.24	PIEC O	00:00:00
02/03/2020	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	17.80	142.23	PIEC O	00:00:00
03/03/2020	0	0.37	28.52	7.03	49.84	0.31	1.06	4.11	13.56	167.51	868.8	15:21:30
04/03/2020	0	0.37	32.02	4.85	48.75	0.32	1.13	3.67	13.83	168.33	869.8	23:55:20
05/03/2020	0	0.37	30.08	4.89	49.51	0.32	1.13	3.41	14.68	164.43	870.5	19:29:10
06/03/2020	0	0.36	24.97	6.10	50.59	0.30	1.19	3.14	13.61	168.44	869.3	23:57:50
07/03/2020	0	0.37	28.58	5.78	50.47	0.28	1.12	2.93	13.62	169.78	865.9	24:00:00
08/03/2020	0	0.37	31.75	5.39	51.36	0.28	1.10	2.90	13.66	169.82	873.4	24:00:00
09/03/2020	0	0.36	32.56	4.84	49.48	0.30	1.16	3.73	14.41	163.85	870.9	14:16:00
10/03/2020	0	0.36	24.15	7.73	50.65	0.34	1.11	5.18	13.98	166.56	869.5	19:29:10
11/03/2020	0	0.36	28.83	6.61	50.19	0.32	1.11	3.03	13.56	168.30	873.0	21:37:30
12/03/2020	0	0.37	30.30	5.47	49.26	0.33	1.12	6.81	13.72	169.19	859.8	18:13:00
13/03/2020	0	0.38	31.01	5.15	49.83	0.31	1.08	3.14	13.89	167.11	865.3	18:39:30
14/03/2020	0	0.38	32.30	5.72	49.12	0.32	1.13	1.32	13.85	171.34	860.5	24:00:00
15/03/2020	0	0.38	32.09	5.26	49.79	0.30	1.12	0.78	13.77	171.42	862.0	23:56:50
16/03/2020	0	0.38	30.13	4.62	50.25	0.29	1.12	0.65	13.80	171.24	866.9	24:00:00
17/03/2020	0	0.37	32.89	3.43	49.43	0.30	1.13	2.58	13.73	171.79	868.3	23:59:40
18/03/2020	0	0.37	31.91	4.05	50.23	0.30	1.13	1.32	13.70	171.13	867.7	21:40:00
19/03/2020	0	0.38	33.73	4.63	49.89	0.31	1.15	0.23	13.76	171.30	865.5	23:51:30
20/03/2020	0	0.38	32.62	3.61	49.32	0.30	1.13	2.29	13.82	169.62	864.1	24:00:00
21/03/2020	0	0.39	29.50	3.28	48.73	0.32	1.14	2.99	14.02	170.01	860.1	24:00:00
22/03/2020	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	Nieważne	17:06:20
23/03/2020	0	0.39	29.15	3.15	49.89	0.32	1.17	1.30	14.01	169.90	865.4	21:10:10
24/03/2020	0	0.39	27.51	5.14	49.99	0.32	1.13	4.04	14.10	168.86	861.6	13:56:50
25/03/2020	0	0.40	28.38	3.64	54.44	0.27	1.20	5.26	14.21	164.20	886.4	18:51:00
26/03/2020	0	0.40	28.04	4.30	53.05	0.28	1.18	4.40	13.96	167.44	875.6	24:00:00
27/03/2020	0	0.39	33.64	3.77	55.02	0.29	1.15	4.09	13.88	168.04	879.4	21:55:10
28/03/2020	0	0.38	33.47	3.82	54.41	0.31	1.16	3.81	13.74	168.40	870.3	24:00:00
29/03/2020	0	0.39	37.33	2.81	55.70	0.31	1.18	3.88	13.90	167.19	868.4	22:56:40
30/03/2020	0	0.41	34.91	3.76	59.96	0.28	1.19	3.72	14.02	165.92	875.0	24:00:00
31/03/2020	0	0.39	30.67	3.83	59.87	0.27	1.16	3.45	13.81	168.06	882.0	24:00:00
Min	0	0.36	24.15	2.81	48.73	0.27	1.06	0.23	13.56	142.23	859.8	
Max	0	0.41	37.33	7.73	59.96	0.34	1.20	6.81	17.80	171.79	886.4	
Sr.	0	0.38	30.75	4.74	51.39	0.30	1.14	3.15	14.10	167.16	869.1	26d
Próg 2		0	0	0	0	0	0	0				00:23:10
Próg 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00				