

Raport Miesięczny

Raport miesięczny
Styczeń 2021

Jedn.	ANALIZATOR : gaz 11% O2								Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	O2 Sec	Temperature	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		10	50	50	200	1	10	10				
PrA3g 1		60	200	100	400	4	20	30				
01/01/2021	1	0.48	24.30	0.51	39.04	0.27	0.54	2.37	8.53	168.25	866.2	23:52:20
02/01/2021	1	0.36	25.21	2.59	57.52	0.42	0.62	2.36	9.21	169.33	868.8	23:59:30
03/01/2021	0	0.29	24.99	7.80	72.42	0.68	0.72	3.04	11.26	168.31	862.0	21:57:20
04/01/2021	0	0.35	23.78	3.25	82.60	0.83	0.68	5.40	11.07	171.78	877.3	24:00:00
05/01/2021	1	0.75	8.01	3.87	64.11	0.52	0.53	2.96	9.20	173.28	884.4	23:59:40
06/01/2021	1	0.75	10.54	2.15	58.65	0.46	0.47	2.51	8.70	171.66	881.2	24:00:00
07/01/2021	1	1.05	7.03	1.68	53.75	0.41	0.48	2.64	8.81	171.97	884.3	24:00:00
08/01/2021	1	1.13	9.81	0.88	52.44	0.41	0.58	3.08	10.48	171.59	881.9	24:00:00
09/01/2021	1	0.94	16.53	2.65	65.66	0.47	0.66	2.91	11.05	171.14	878.5	23:29:10
10/01/2021	0	0.32	24.73	6.96	76.52	0.43	0.70	2.43	11.38	170.19	864.5	23:59:50
11/01/2021	0	0.30	20.12	6.13	77.61	0.42	0.70	2.42	11.37	169.36	863.3	24:00:00
12/01/2021	0	0.31	23.81	9.55	72.09	0.48	0.72	2.54	11.50	170.65	867.1	24:00:00
13/01/2021	0	0.29	24.24	8.28	64.82	0.51	0.71	2.46	11.39	170.95	868.7	24:00:00
14/01/2021	0	0.27	20.49	7.96	69.70	0.46	0.72	2.47	11.45	170.12	870.1	24:00:00
15/01/2021	0	0.40	26.03	7.61	67.75	0.49	0.71	2.40	11.42	169.95	864.5	24:00:00
16/01/2021	0	0.51	23.72	6.34	61.98	0.52	0.70	2.34	11.35	169.68	865.3	23:59:50
17/01/2021	0	0.36	25.94	6.93	66.58	0.50	0.71	2.39	11.40	167.80	859.8	23:59:50
18/01/2021	0	0.34	22.11	5.80	60.71	0.48	0.70	2.35	11.36	163.40	859.2	24:00:00
19/01/2021	0	0.27	24.01	5.19	71.26	0.44	0.73	2.42	11.48	165.91	861.3	24:00:00
20/01/2021	0	0.27	25.46	4.79	75.21	0.42	0.72	2.47	11.45	167.37	859.5	24:00:00
21/01/2021	0	0.26	27.46	4.88	85.99	0.41	0.72	2.55	11.43	169.05	863.3	24:00:00
22/01/2021	0	0.25	24.03	3.59	84.81	0.41	0.69	2.66	11.21	170.88	872.3	24:00:00
23/01/2021	0	0.25	24.48	4.40	85.39	0.40	0.71	2.57	11.30	171.49	872.2	24:00:00
24/01/2021	0	0.26	31.49	2.54	82.42	0.42	0.69	2.42	11.19	171.29	873.7	24:00:00
25/01/2021	0	0.36	26.11	4.43	74.63	0.44	0.69	2.39	11.12	169.42	872.0	23:58:30
26/01/2021	0	0.58	15.72	3.84	47.28	0.36	0.52	1.97	8.32	165.19	864.2	24:00:00
27/01/2021	1	0.82	11.41	0.18	26.06	0.16	0.22	1.44	6.48	154.96	859.0	17:39:10
28/01/2021	1	0.61	20.00	1.50	33.57	0.30	0.53	8.52	9.08	162.97	873.7	19:22:30
29/01/2021	1	0.78	20.36	1.47	39.64	0.33	0.65	5.18	10.33	165.09	866.6	23:54:20
30/01/2021	1	0.70	20.30	2.10	51.89	0.37	0.65	3.57	10.55	167.18	881.3	23:59:30
31/01/2021	1	0.69	22.65	1.56	46.35	0.33	0.67	2.81	10.51	157.62	868.3	10:59:40
Min	0	0.25	7.03	0.18	26.06	0.16	0.22	1.44	6.48	154.96	859.0	
Max	1	1.13	31.49	9.55	85.99	0.83	0.73	8.52	11.50	173.28	884.4	
Sr.	0	0.49	21.12	4.24	63.50	0.44	0.64	2.90	10.50	168.32	869.5	29d
PrA3g 2		0	0	0	0	0	0	0				21:11:10
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:30				