

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Styczeń 2025

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatu	T2S	PIEC
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		8	40	50	180	1	10	5		20				
PrA3g 1		60	200	100	400	4	20	30						
01/01/2025	1	2.98	25.32	4.13	29.41	0.42	1.40	1.99	2.95	2.97	11.25	156.65	899.0	24:00:00
02/01/2025	1	2.19	23.83	4.63	27.07	0.37	1.41	1.99	3.00	3.04	11.32	155.68	891.0	22:57:30
03/01/2025	1	1.84	20.03	4.39	28.65	0.34	1.43	2.96	6.37	3.13	11.63	151.19	888.6	17:21:50
04/01/2025	1	3.13	24.30	4.19	28.56	0.37	1.46	2.12	9.39	2.97	11.39	155.45	880.1	24:00:00
05/01/2025	1	3.49	23.55	4.01	28.87	0.39	1.11	2.01	8.44	2.94	11.22	155.56	882.5	24:00:00
06/01/2025	1	3.68	25.18	4.17	28.60	0.39	1.43	1.98	5.86	6.68	11.25	154.45	883.8	24:00:00
07/01/2025	1	3.22	22.14	5.02	26.47	0.35	1.25	1.96	3.89	2.92	11.46	152.22	884.6	24:00:00
08/01/2025	1	2.94	24.36	4.87	28.04	0.35	1.44	2.12	3.25	2.92	11.74	152.44	886.8	20:41:00
09/01/2025	1	1.83	18.89	5.34	27.02	0.32	1.42	2.44	4.12	2.82	12.02	150.12	880.6	14:27:20
10/01/2025	1	1.33	23.22	4.86	27.73	0.32	0.98	2.13	9.64	2.88	10.46	162.81	888.4	24:00:00
11/01/2025	1	1.37	22.86	5.81	19.44	0.35	1.06	1.59	5.04	2.39	10.13	161.03	884.5	22:29:40
12/01/2025	1	2.75	25.61	3.84	31.21	0.34	1.48	2.02	11.34	3.07	11.42	161.45	878.9	24:00:00
13/01/2025	1	2.55	23.82	4.11	30.63	0.38	1.54	2.01	11.21	8.16	11.53	161.07	878.2	24:00:00
14/01/2025	1	3.29	22.91	4.56	29.33	0.41	1.42	2.02	8.19	3.07	11.44	161.41	886.4	24:00:00
15/01/2025	1	3.97	24.91	4.29	29.99	0.39	1.47	2.08	10.09	3.07	11.36	162.57	887.4	24:00:00
16/01/2025	1	2.92	25.84	4.41	30.25	0.36	1.45	2.65	5.77	3.08	12.19	154.89	882.8	15:49:00
17/01/2025	1	1.98	25.45	4.91	29.11	0.35	1.49	2.20	7.93	3.23	11.41	161.94	888.0	24:00:00
18/01/2025	1	2.09	26.21	4.15	30.73	0.34	1.44	2.05	9.22	3.09	11.40	161.78	882.4	24:00:00
19/01/2025	1	2.27	24.53	3.98	30.59	0.34	1.46	2.03	10.74	3.06	11.37	162.10	877.0	24:00:00
20/01/2025	1	2.18	22.23	4.71	30.09	0.34	1.38	2.47	6.51	7.58	11.85	156.04	877.7	17:04:30
21/01/2025	1	0.96	23.36	5.47	31.09	0.30	1.31	2.06	5.90	2.95	10.84	160.51	884.9	24:00:00
22/01/2025	1	1.58	24.23	4.36	37.86	0.34	1.45	1.99	5.90	3.03	11.23	160.50	885.2	24:00:00
23/01/2025	1	1.63	23.61	4.39	37.36	0.33	1.42	2.00	5.76	3.02	11.20	160.48	883.6	24:00:00
24/01/2025	1	2.09	24.27	4.21	38.01	0.36	1.44	2.00	5.44	3.02	11.24	161.33	887.1	24:00:00
25/01/2025	1	2.74	24.47	4.13	38.22	0.38	1.26	2.01	6.97	3.02	11.26	161.45	880.7	24:00:00
26/01/2025	1	3.34	24.53	5.00	35.43	0.38	1.39	2.00	5.40	3.00	11.31	161.14	878.9	24:00:00
27/01/2025	1	1.96	25.85	4.10	35.92	0.33	1.56	2.48	6.48	9.38	12.04	155.56	861.6	16:45:50
28/01/2025	1	0.86	23.47	4.31	38.02	0.34	1.36	2.12	6.30	2.99	11.13	160.15	891.1	24:00:00
29/01/2025	1	1.64	23.96	4.40	37.62	0.37	1.30	2.06	6.01	3.02	11.30	159.73	897.4	23:10:20
30/01/2025	1	1.61	23.96	4.52	36.69	0.36	1.59	2.14	5.16	3.03	11.52	158.61	892.9	22:20:10
31/01/2025	1	2.35	24.25	4.80	36.19	0.37	1.34	2.01	4.88	3.06	11.49	159.16	895.4	22:58:40
Min	1	0.86	18.89	3.84	19.44	0.30	0.98	1.59	2.95	2.39	10.13	150.12	861.6	
Max	1	3.97	26.21	5.81	38.22	0.42	1.59	2.96	11.34	9.38	12.19	162.81	899.0	
Sr.	1	2.35	23.91	4.52	31.43	0.36	1.39	2.12	6.68	3.63	11.37	158.37	884.8	29d
PrA3g 2		0	0	0	0	0	0	0		0				00:05:50
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00						