

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Luty 2025

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatu	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		8	40	50	180	1	10	5		20				
PrA3g 1		60	200	100	400	4	20	30						
01/02/2025	1	3.39	24.21	4.15	38.63	0.38	1.52	2.00	5.09	3.10	11.47	159.43	896.3	24:00:00
02/02/2025	1	3.86	24.50	4.90	34.17	0.39	1.44	1.99	4.72	3.06	11.47	158.86	889.0	24:00:00
03/02/2025	1	2.88	22.26	4.89	35.32	0.36	1.53	2.30	2.96	7.90	12.32	147.62	892.6	15:03:40
04/02/2025	1	1.69	21.34	4.43	38.00	0.33	1.64	2.07	3.70	3.11	11.55	157.51	895.0	24:00:00
05/02/2025	1	2.04	22.13	4.50	37.16	0.35	1.58	2.00	4.20	3.11	11.62	157.44	884.9	24:00:00
06/02/2025	1	2.38	24.95	4.04	38.03	0.36	1.67	1.99	4.66	3.12	11.62	157.87	880.8	24:00:00
07/02/2025	1	2.75	22.93	4.01	40.34	0.40	1.65	1.99	3.00	3.10	11.53	158.77	896.3	24:00:00
08/02/2025	1	3.34	26.63	4.17	38.52	0.41	1.68	2.01	3.55	3.12	11.57	158.90	887.7	24:00:00
09/02/2025	1	4.10	25.85	4.34	37.43	0.42	1.62	2.01	2.83	3.10	11.64	158.33	884.6	23:55:00
10/02/2025	1	3.10	22.74	3.91	38.09	0.37	1.37	2.17	2.74	10.94	13.06	136.72	870.5	09:44:10
11/02/2025	1	0.73	24.02	4.71	38.44	0.33	1.62	2.14	2.97	3.11	11.63	156.99	896.4	22:32:20
12/02/2025	1	2.22	23.57	4.44	38.96	0.40	1.64	2.02	3.14	3.13	11.52	158.07	897.2	24:00:00
13/02/2025	1	2.46	23.76	4.99	37.82	0.38	1.57	2.02	3.35	3.09	11.42	158.98	897.4	24:00:00
14/02/2025	1	3.30	23.22	4.86	38.91	0.42	1.58	1.96	2.50	3.02	11.07	158.85	902.3	23:53:50
15/02/2025	1	3.94	18.32	4.26	39.95	0.39	1.63	2.02	2.84	3.11	11.57	158.58	900.3	23:21:20
16/02/2025	1	4.35	22.79	4.79	36.44	0.40	1.70	2.01	4.00	3.12	11.67	158.68	890.8	24:00:00
17/02/2025	1	2.27	20.53	3.98	38.50	0.34	1.60	2.72	3.47	8.55	12.49	151.83	884.1	14:31:20
18/02/2025	1	1.25	25.72	4.26	39.46	0.34	1.64	2.15	4.07	3.13	11.59	157.81	898.0	24:00:00
19/02/2025	1	2.57	23.24	4.39	39.27	0.41	1.66	2.04	3.24	3.16	11.66	158.41	900.2	24:00:00
20/02/2025	1	2.74	22.97	4.20	39.55	0.41	1.67	2.04	3.39	3.16	11.66	158.42	898.3	24:00:00
21/02/2025	1	3.60	20.04	4.00	40.23	0.43	1.66	2.05	3.43	3.17	11.71	158.84	896.5	24:00:00
22/02/2025	1	4.77	28.38	4.00	38.96	0.48	1.63	2.03	4.42	3.16	11.74	159.36	884.0	24:00:00
23/02/2025	1	4.59	18.61	3.86	38.54	0.42	1.60	2.02	3.97	3.16	11.97	157.55	873.8	24:00:00
24/02/2025	1	3.11	20.85	3.90	39.91	0.38	1.52	2.40	3.09	7.80	12.85	138.73	885.3	12:58:40
25/02/2025	1	1.17	25.06	4.19	41.36	0.35	1.63	2.22	3.29	3.16	11.57	159.14	901.2	24:00:00
26/02/2025	1	2.33	24.02	4.16	42.16	0.40	1.62	2.07	2.70	3.14	11.57	158.92	904.0	24:00:00
27/02/2025	1	3.13	23.27	3.99	42.73	0.43	1.64	2.08	2.57	3.16	11.63	159.82	901.1	24:00:00
28/02/2025	1	4.29	20.60	4.29	40.45	0.44	1.57	2.08	3.72	3.17	11.71	160.04	892.9	24:00:00
Min	1	0.73	18.32	3.86	34.17	0.33	1.37	1.96	2.50	3.02	11.07	136.72	870.5	
Max	1	4.77	28.38	4.99	42.73	0.48	1.70	2.72	5.09	10.94	13.06	160.04	904.0	
Sr.	1	2.94	23.09	4.31	38.83	0.39	1.60	2.09	3.49	3.93	11.75	156.45	892.2	26d
PrA3g 2		0	0	0	0	0	0	0	0	0				02:00:20
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00						