

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny Marzec 2025

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		8	40	50	180	1	10	5		20				
PrA3g 1		60	200	100	400	4	20	30						
01/03/2025	1	4.70	18.32	3.95	41.27	0.44	1.63	2.03	3.55	3.18	12.03	157.13	882.4	24:00:00
02/03/2025	1	4.61	13.33	4.45	37.45	0.40	1.69	2.04	2.42	3.23	12.31	155.33	878.3	24:00:00
03/03/2025	1	3.13	22.51	4.51	36.86	0.37	1.66	2.42	2.66	9.40	12.62	151.23	884.5	17:52:20
04/03/2025	1	2.31	22.62	4.67	38.51	0.38	1.69	2.13	3.18	3.18	12.04	153.19	905.2	24:00:00
05/03/2025	1	3.58	20.76	4.07	39.76	0.43	1.55	2.08	3.30	3.17	11.93	157.83	898.3	24:00:00
06/03/2025	1	4.71	18.25	3.97	40.01	0.44	1.90	2.07	2.92	3.16	11.93	159.37	894.5	24:00:00
07/03/2025	1	2.52	14.59	3.90	41.18	0.38	2.27	2.45	2.47	3.09	12.36	154.50	896.2	16:37:00
08/03/2025	1	1.23	17.96	4.09	40.98	0.35	1.67	2.13	3.11	3.16	11.69	158.70	896.6	24:00:00
09/03/2025	1	3.27	23.17	3.97	40.33	0.47	1.74	2.08	3.36	3.14	11.68	159.50	885.8	24:00:00
10/03/2025	1	2.62	17.55	3.86	42.05	0.38	1.44	2.60	2.42	8.74	12.64	151.00	877.8	13:07:50
11/03/2025	1	0.99	22.21	3.94	41.54	0.31	1.58	2.20	3.23	3.13	11.67	158.94	885.6	24:00:00
12/03/2025	1	1.34	17.84	3.83	41.53	0.34	1.68	2.26	3.74	3.12	11.67	158.89	884.3	24:00:00
13/03/2025	1	1.91	21.65	4.08	42.16	0.40	1.63	2.08	2.41	3.08	11.52	159.32	897.9	23:54:40
14/03/2025	1	3.21	21.96	4.08	41.98	0.41	1.64	2.06	2.15	3.13	11.82	156.98	892.4	22:58:10
15/03/2025	1	4.03	23.55	4.18	41.23	0.40	1.64	2.06	3.11	3.17	11.72	158.46	893.3	24:00:00
16/03/2025	1	4.11	18.77	3.92	41.30	0.41	1.62	2.10	2.35	3.18	11.82	158.63	884.8	24:00:00
17/03/2025	1	2.32	22.01	4.11	37.96	0.33	1.57	2.68	2.13	11.04	12.99	149.64	862.6	12:27:40
18/03/2025	1	1.04	25.94	4.11	40.54	0.35	1.61	2.36	2.87	3.25	12.05	157.66	887.7	23:22:40
19/03/2025	1	2.14	23.74	4.33	40.66	0.40	1.65	2.16	2.18	3.18	11.76	158.75	901.8	24:00:00
20/03/2025	1	2.43	22.37	4.35	39.36	0.39	1.63	2.27	2.34	3.15	11.70	156.07	897.2	19:25:40
21/03/2025	1	3.34	20.47	5.86	39.95	0.45	1.73	2.17	1.90	3.06	11.71	158.11	901.7	22:03:30
22/03/2025	1	4.21	22.12	4.74	38.61	0.42	1.34	2.02	1.85	3.06	11.67	157.92	888.3	21:26:00
23/03/2025	1	3.19	19.29	5.11	35.52	0.34	1.53	2.01	1.95	3.08	12.04	155.01	861.4	24:00:00
24/03/2025	1	2.02	15.34	4.02	38.27	0.31	1.39	2.80	1.90	7.90	12.51	147.32	868.3	14:42:30
25/03/2025	1	0.71	21.91	5.53	35.92	0.30	1.51	2.14	1.90	3.19	11.76	151.99	890.3	24:00:00
26/03/2025	1	1.05	20.64	4.62	37.23	0.33	1.63	2.27	1.92	3.09	12.55	134.38	887.2	16:05:30
27/03/2025	1	2.38	21.65	5.01	38.13	0.41	1.57	2.12	2.30	3.09	11.65	155.26	897.9	24:00:00
28/03/2025	1	3.23	21.35	4.54	38.12	0.40	1.46	2.08	2.75	3.10	11.94	154.61	879.4	22:52:20
29/03/2025	1	2.38	17.26	7.49	33.09	0.31	1.55	2.05	3.38	3.10	12.17	153.00	863.0	23:59:40
30/03/2025	1	2.20	13.79	6.19	32.09	0.28	1.35	2.09	2.89	3.10	12.32	150.82	858.0	22:52:10
31/03/2025	1	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	4.26	13.47	152.63	PIEC O	00:00:00
Min	1	0.71	13.33	3.83	32.09	0.28	1.34	2.01	1.85	3.06	11.52	134.38	858.0	27d 06:47:40
Max	1	4.71	25.94	7.49	42.16	0.47	2.27	2.80	3.74	11.04	13.47	159.50	905.2	
Sr.	1	2.70	20.10	4.52	39.12	0.38	1.62	2.20	2.62	3.96	12.06	154.91	886.1	
PrA3g 2		0	0	0	0	0	0	0		0				
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00						