

WMK Krakow STUO
Raport Miesieczny

Raport miesieczny

Październik 2025

Jedn.	ANALIZATOR : gaz 11% O2										Proces			
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S	PIEC
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC	hh:mm:ss
PrA3g 2		8	40	50	180	1	10	5						
PrA3g 1		60	200	100	400	4	20	30		20				
01/10/2025	0	1.42	26.05	20.05	27.73	0.25	0.59	1.93	37.25	3.31	10.84	168.70	914.7	24:00:00
02/10/2025	0	1.32	24.55	13.35	27.29	0.24	0.57	1.83	36.79	3.11	10.92	165.30	895.6	24:00:00
03/10/2025	0	1.38	27.03	14.98	28.99	0.24	0.59	1.91	37.18	3.25	10.86	167.13	911.5	23:51:10
04/10/2025	0	1.19	26.73	13.55	28.02	0.24	0.58	1.89	36.78	3.06	10.74	168.12	910.3	24:00:00
05/10/2025	0	0.80	27.24	3.67	21.54	0.25	0.55	1.79	33.03	2.89	10.70	166.86	905.1	23:53:00
06/10/2025	0	1.30	21.00	10.79	23.83	0.34	0.55	1.77	23.38	2.80	11.03	161.09	898.3	21:17:30
07/10/2025	0	1.63	27.37	28.75	40.04	0.25	0.60	1.96	37.73	3.40	10.94	168.62	912.3	24:00:00
08/10/2025	1	1.09	24.18	22.79	36.24	0.33	1.12	1.96	36.58	3.26	10.72	168.89	912.3	23:36:00
09/10/2025	1	0.76	23.10	18.22	34.77	0.37	1.41	1.95	35.76	3.07	10.53	169.65	912.8	24:00:00
10/10/2025	1	0.91	21.23	17.37	34.58	0.37	1.40	1.95	36.14	2.96	10.61	169.46	910.4	24:00:00
11/10/2025	1	0.87	25.57	14.05	32.46	0.35	1.24	1.93	36.10	3.02	10.64	170.16	907.7	23:39:50
12/10/2025	0	1.50	26.91	12.67	44.86	0.25	0.60	1.92	37.68	3.10	10.94	168.27	896.9	24:00:00
13/10/2025	0	1.57	21.56	10.27	37.92	0.25	0.60	1.92	37.82	4.63	10.96	166.71	900.7	24:00:00
14/10/2025	0	1.43	25.89	14.30	28.64	0.25	0.59	1.84	37.01	3.05	11.01	164.28	900.2	22:08:50
15/10/2025	0	1.56	28.49	27.42	35.48	0.25	0.60	2.29	35.92	2.84	11.88	139.61	903.1	11:28:00
16/10/2025	0	1.16	23.81	26.04	25.98	0.24	0.59	1.97	36.85	3.00	10.79	166.46	908.0	23:51:10
17/10/2025	0	1.01	21.49	23.52	21.01	0.23	0.57	1.86	36.51	2.93	10.70	167.15	907.1	23:49:00
18/10/2025	0	0.78	21.51	15.72	22.10	0.25	0.74	1.99	35.81	2.87	10.62	166.84	906.2	23:21:50
19/10/2025	0	1.01	23.40	12.80	22.24	0.23	0.56	1.86	36.63	2.91	10.72	166.75	903.0	23:48:40
20/10/2025	0	0.80	21.95	11.52	23.70	0.23	0.55	1.80	36.10	3.44	10.60	167.35	903.2	24:00:00
21/10/2025	0	0.87	22.65	11.57	25.16	0.23	0.56	1.85	36.37	2.90	10.65	168.08	905.8	24:00:00
22/10/2025	0	1.20	26.33	16.36	26.76	0.25	0.59	1.95	37.53	3.06	10.89	168.43	908.2	24:00:00
23/10/2025	0	1.18	24.82	21.38	30.21	0.25	0.59	2.22	37.80	3.36	11.07	166.74	907.6	21:50:50
24/10/2025	1	0.64	23.68	20.32	31.11	0.29	1.07	2.12	35.66	2.88	10.51	168.35	909.4	23:48:10
25/10/2025	1	0.52	25.53	25.55	35.93	0.34	1.41	2.02	35.43	2.90	10.46	170.22	909.5	23:56:00
26/10/2025	1	0.78	25.09	32.45	31.57	0.29	1.34	2.01	36.24	2.95	10.61	171.45	911.9	1d 01:00:00
27/10/2025	0	0.77	19.63	22.34	24.00	0.23	0.55	1.91	35.80	4.72	10.53	169.72	908.4	24:00:00
28/10/2025	0	0.95	23.85	25.80	31.36	0.28	0.85	2.08	36.92	3.00	10.77	171.21	914.1	24:00:00
29/10/2025	0	1.35	21.35	23.04	30.92	0.25	0.60	2.02	37.93	3.10	10.99	170.39	907.0	23:51:20
30/10/2025	0	1.04	27.29	22.64	35.51	0.29	0.99	2.00	37.83	3.09	10.96	170.95	902.5	24:00:00
31/10/2025	0	1.32	21.85	21.80	31.50	0.26	0.80	1.97	38.29	3.12	11.05	170.83	900.9	23:48:50
Min	0	0.52	19.63	3.67	21.01	0.23	0.55	1.77	23.38	2.80	10.46	139.61	895.6	30d 03:00:10
Max	1	1.63	28.49	32.45	44.86	0.37	1.41	2.29	38.29	4.72	11.88	171.45	914.7	
Sr.	0	1.10	24.23	18.55	30.05	0.27	0.77	1.95	36.22	3.16	10.81	167.22	906.6	
PrA3g 2		0	0	0	0	0	0	0		0				
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00						