

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Marzec 2026**

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur T2S	T2S
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
<b>PrA3g 2</b>	<b>8</b>	<b>40</b>	<b>50</b>	<b>180</b>	<b>1</b>	<b>10</b>	<b>5</b>	<b>20</b>					
<b>PrA3g 1</b>	<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>			<b>20</b>			
01/03/2026	0	1.04	19.11	9.29	56.07	0.20	0.52	0.87	4.62	0.63	10.03	155.88	896.6
02/03/2026	0	1.01	19.39	9.28	54.77	0.20	0.52	1.37	3.95	0.71	10.14	154.57	892.2
03/03/2026	0	1.01	19.75	9.47	53.43	0.20	0.53	1.56	5.39	0.70	10.00	157.76	893.9
04/03/2026	0	1.01	25.05	9.56	54.75	0.20	0.52	1.79	5.68	0.81	10.21	157.21	897.6
05/03/2026	0	0.91	20.14	9.30	54.04	0.20	0.53	1.60	6.68	0.75	9.96	161.14	902.1
06/03/2026	0	0.90	19.63	9.70	53.12	0.20	0.53	1.57	6.94	0.66	10.84	127.81	896.8
07/03/2026	0	0.65	20.72	9.28	51.76	0.20	0.52	2.04	7.62	0.65	10.67	136.15	900.6
08/03/2026	0	1.06	21.62	9.19	54.16	0.20	0.52	1.56	5.45	0.67	10.14	158.65	895.1
09/03/2026	0	0.90	23.66	9.32	51.95	0.20	0.53	1.59	7.72	0.69	9.98	161.25	892.8
10/03/2026	0	1.08	15.00	9.22	59.10	0.20	0.52	1.63	3.43	0.70	11.23	145.83	885.0
11/03/2026	0	0.82	24.47	9.42	53.36	0.21	0.53	1.71	6.71	0.90	10.06	160.49	903.3
12/03/2026	0	0.76	24.23	9.42	53.18	0.21	0.53	1.61	6.54	0.91	9.96	162.08	908.7
13/03/2026	0	0.58	21.15	9.46	51.88	0.21	0.54	1.62	8.93	1.01	9.94	162.89	906.5
14/03/2026	0	0.87	23.42	9.40	54.90	0.21	0.53	1.61	6.40	1.00	9.96	162.59	906.6
15/03/2026	0	1.17	21.46	9.32	56.00	0.20	0.52	1.57	3.82	0.90	10.04	160.22	897.2
16/03/2026	0	1.05	23.58	9.45	56.76	0.20	0.52	1.54	3.82	1.02	10.63	154.80	882.7
17/03/2026	0	1.06	13.49	9.29	54.98	0.20	0.53	1.54	4.58	0.85	10.12	159.08	886.0
18/03/2026	0	0.99	23.54	9.32	54.22	0.20	0.53	1.54	3.66	0.94	9.99	159.89	897.8
19/03/2026	0	0.74	24.28	9.51	51.62	0.21	0.53	1.58	5.07	1.10	9.87	162.30	906.3
20/03/2026	0	0.92	23.94	9.38	54.57	0.21	0.53	1.59	5.02	1.18	9.94	163.27	908.1
21/03/2026	0	0.93	21.02	9.36	55.35	0.21	0.53	1.59	5.55	1.14	9.98	162.94	906.8
22/03/2026	0	1.05	26.27	9.32	55.48	0.20	0.53	1.77	5.25	1.15	10.10	160.38	904.7
23/03/2026	0	1.14	23.90	9.31	56.73	0.20	0.53	1.60	5.15	1.16	10.06	161.11	904.4
24/03/2026	0	1.15	23.75	9.43	57.20	0.20	0.53	2.00	5.00	1.12	11.08	146.94	895.7
25/03/2026	0	1.18	19.85	10.35	58.55	0.21	0.53	1.73	4.30	1.08	10.28	158.83	902.2
26/03/2026	0	1.21	22.07	9.60	59.03	0.21	0.54	1.84	4.53	1.08	11.45	147.13	894.0
27/03/2026	0	1.33	24.73	9.39	58.15	0.21	0.54	1.60	4.09	1.27	10.33	157.52	912.2
28/03/2026	0	1.23	24.62	9.44	58.83	0.21	0.54	1.59	4.33	1.27	10.06	160.37	918.0
29/03/2026	0	1.13	24.54	9.43	56.32	0.21	0.53	1.60	4.68	1.43	10.01	161.66	914.4
30/03/2026	0	0.84	22.57	9.52	52.99	0.21	0.54	1.61	5.72	1.32	10.12	155.26	908.9
31/03/2026	0	0.97	22.20	9.63	50.25	0.21	0.55	1.62	7.35	1.16	9.55	160.77	908.0
<b>Min</b>	<b>0</b>	<b>0.58</b>	<b>13.49</b>	<b>9.19</b>	<b>50.25</b>	<b>0.20</b>	<b>0.52</b>	<b>0.87</b>	<b>3.43</b>	<b>0.63</b>	<b>9.55</b>	<b>127.81</b>	<b>882.7</b>
<b>Max</b>	<b>0</b>	<b>1.33</b>	<b>26.27</b>	<b>10.35</b>	<b>59.10</b>	<b>0.21</b>	<b>0.55</b>	<b>2.04</b>	<b>8.93</b>	<b>1.43</b>	<b>11.45</b>	<b>163.27</b>	<b>918.0</b>
<b>Sr.</b>	<b>0</b>	<b>0.99</b>	<b>22.04</b>	<b>9.43</b>	<b>54.95</b>	<b>0.20</b>	<b>0.53</b>	<b>1.61</b>	<b>5.42</b>	<b>0.97</b>	<b>10.22</b>	<b>156.67</b>	<b>900.8</b>
<b>PrA3g 2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			
<b>Wskaznik</b>	<b>0</b>	<b>0.97</b>	<b>22.20</b>	<b>9.63</b>	<b>50.25</b>	<b>0.21</b>	<b>0.55</b>	<b>1.62</b>	<b>7.35</b>	<b>1.16</b>	<b>9.55</b>	<b>160.77</b>	<b>908.0</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>					