

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Styczeń 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2	8	40	50	180	1	10	5			20			
PrA3g 1	60	200	100	400	4	20	30						
01/01/2026	0	0.44	11.58	9.41	45.34	0.21	0.53	1.71	10.31	0.29	9.73	159.02	886.0
02/01/2026	0	0.44	12.75	9.37	47.24	0.20	0.53	1.71	5.58	9.86	9.49	162.42	908.4
03/01/2026	0	0.45	15.93	9.38	46.16	0.21	0.53	1.69	6.13	1.49	9.62	161.86	901.0
04/01/2026	0	0.50	18.94	9.35	45.95	0.21	0.53	1.74	6.56	0.46	9.72	160.11	897.8
05/01/2026	0	0.71	17.05	9.66	47.54	0.21	0.54	2.14	6.79	0.44	9.69	159.94	901.6
06/01/2026	0	0.53	18.99	9.41	46.41	0.21	0.53	1.98	5.39	0.38	9.77	158.21	907.7
07/01/2026	0	0.65	24.03	10.36	47.72	0.21	0.54	1.71	5.32	0.38	9.61	162.15	912.7
08/01/2026	0	0.51	19.50	9.31	46.50	0.20	0.52	1.63	3.50	0.42	9.43	163.78	915.7
09/01/2026	0	0.46	20.43	9.34	46.97	0.20	0.53	1.63	4.54	0.36	9.54	163.66	912.6
10/01/2026	0	0.49	19.64	9.40	46.81	0.20	0.53	1.62	4.38	0.93	9.51	163.74	915.4
11/01/2026	0	0.47	23.02	9.33	45.22	0.21	0.53	1.60	4.87	0.49	9.60	163.31	905.9
12/01/2026	0	0.51	21.93	9.29	44.83	0.20	0.52	1.57	4.90	0.40	9.55	160.92	908.0
13/01/2026	0	0.53	21.22	9.40	44.99	0.20	0.53	1.57	4.94	0.40	9.50	160.76	909.9
14/01/2026	0	0.65	20.65	10.14	45.80	0.21	0.53	1.60	4.90	0.42	9.57	161.79	912.7
15/01/2026	0	0.79	22.56	10.35	48.19	0.21	0.55	1.64	5.01	0.43	9.65	162.63	914.4
16/01/2026	0	0.90	19.69	10.54	49.68	0.21	0.55	1.66	4.33	0.46	9.70	162.68	918.6
17/01/2026	0	1.06	18.93	12.25	54.81	0.22	0.56	1.71	5.52	0.45	9.80	162.68	920.0
18/01/2026	0	0.88	23.35	10.34	48.32	0.21	0.54	1.61	4.76	0.38	9.60	160.78	919.1
19/01/2026	0	0.52	24.23	9.28	44.02	0.20	0.52	1.53	3.76	0.40	9.46	159.65	912.2
20/01/2026	0	0.84	20.83	11.05	50.33	0.21	0.55	1.66	5.63	0.48	9.60	161.92	906.9
21/01/2026	0	0.63	16.92	10.26	47.20	0.21	0.53	1.86	5.99	0.48	9.63	160.10	906.2
22/01/2026	0	0.88	21.15	12.60	49.70	0.21	0.55	1.75	8.81	0.52	9.62	163.47	917.2
23/01/2026	0	0.65	19.28	10.26	46.79	0.20	0.52	1.63	6.07	0.49	9.39	163.50	925.6
24/01/2026	0	0.92	16.93	11.46	51.51	0.21	0.55	2.01	7.61	0.54	9.81	161.08	921.2
25/01/2026	0	0.81	16.17	10.46	51.22	0.21	0.54	1.76	7.83	0.53	9.65	163.63	920.6
26/01/2026	0	1.06	21.60	11.69	54.45	0.22	0.56	1.98	8.43	0.58	9.86	163.17	923.5
27/01/2026	0	0.96	25.93	10.95	66.00	0.22	0.56	1.98	9.06	0.53	10.39	146.94	924.2
28/01/2026	0	0.57	22.90	9.48	53.65	0.21	0.53	1.86	9.81	0.48	9.98	158.03	924.0
29/01/2026	0	0.59	18.83	9.49	51.84	0.21	0.53	2.28	10.72	0.59	10.03	153.97	915.0
30/01/2026	0	0.57	21.98	9.58	50.38	0.21	0.53	1.65	10.79	0.50	9.52	161.71	925.4
31/01/2026	0	0.50	19.95	9.39	48.02	0.21	0.53	1.59	8.90	0.47	9.63	159.62	913.4
Min	0	0.44	11.58	9.28	44.02	0.20	0.52	1.53	3.50	0.29	9.39	146.94	886.0
Max	0	1.06	25.93	12.60	66.00	0.22	0.56	2.28	10.79	9.86	10.39	163.78	925.6
Sr.	0	0.66	19.90	10.08	48.83	0.21	0.54	1.74	6.49	0.81	9.67	160.88	913.0
PrA3g 2	0	0	0	0	0	0	0	0	0	0			
Wskaznik	0	0.50	19.95	9.39	48.02	0.21	0.53	1.59	8.90	0.47	9.63	159.62	913.4
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					