

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny
Luty 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur T2S	T2S
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2	8	40	50	180	1	10	5	20	5	20			
PrA3g 1	60	200	100	400	4	20	30						
01/02/2026	0	0.60	20.92	9.40	48.75	0.21	0.53	2.08	6.87	0.43	10.54	150.98	901.3
02/02/2026	0	0.58	21.10	9.40	49.81	0.21	0.54	1.63	6.10	0.49	9.72	158.96	917.7
03/02/2026	0	0.58	20.43	9.43	49.88	0.21	0.53	1.62	7.16	0.50	9.63	159.90	919.0
04/02/2026	0	0.56	21.53	9.39	50.52	0.21	0.53	1.62	6.50	0.54	9.55	161.07	922.7
05/02/2026	0	0.66	17.55	10.11	53.29	0.21	0.54	1.64	5.33	0.54	9.71	160.80	918.7
06/02/2026	0	0.70	22.02	9.56	53.55	0.21	0.54	1.64	4.44	0.43	9.94	159.90	910.2
07/02/2026	0	0.53	16.03	9.58	51.27	0.21	0.54	1.63	6.35	0.50	9.73	160.59	917.7
08/02/2026	0	0.59	20.05	9.48	49.79	0.21	0.53	1.61	7.27	0.48	9.55	161.63	913.5
09/02/2026	0	0.58	16.19	9.49	48.57	0.20	0.54	1.59	9.17	0.46	9.49	161.35	910.3
10/02/2026	0	0.51	21.36	9.60	50.29	0.21	0.54	1.61	7.67	0.47	9.55	162.15	915.8
11/02/2026	0	0.70	19.21	9.40	54.30	0.21	0.53	1.73	6.30	0.58	9.74	161.54	917.3
12/02/2026	0	0.66	21.57	9.54	54.65	0.21	0.54	1.71	5.29	0.63	9.78	163.73	917.5
13/02/2026	0	0.58	18.46	9.49	53.04	0.21	0.54	1.67	7.96	0.68	9.62	164.92	915.3
14/02/2026	0	0.62	18.38	9.48	49.78	0.21	0.53	1.63	6.85	0.60	9.60	162.97	914.1
15/02/2026	0	0.67	16.72	9.71	48.97	0.21	0.53	1.60	7.29	0.49	9.64	160.36	907.4
16/02/2026	0	0.73	19.71	9.30	52.76	0.20	0.53	1.59	4.03	0.51	9.64	159.46	911.4
17/02/2026	0	0.69	22.63	9.36	52.09	0.21	0.53	1.60	3.43	0.60	9.66	160.23	909.8
18/02/2026	0	0.62	21.03	9.31	51.26	0.20	0.53	1.58	4.63	0.62	9.94	158.64	904.5
19/02/2026	0	0.47	18.42	9.25	50.78	0.20	0.50	1.50	5.94	0.61	9.60	159.91	907.5
20/02/2026	0	0.66	25.45	11.30	50.96	0.20	0.53	1.55	8.02	0.57	9.51	160.39	911.0
21/02/2026	0	0.65	18.18	19.00	51.23	0.20	0.53	1.56	9.26	0.63	9.52	159.84	909.9
22/02/2026	0	0.64	24.13	9.65	51.39	0.21	0.53	1.58	8.28	0.67	9.54	161.56	907.1
23/02/2026	0	0.66	23.24	9.51	54.71	0.21	0.51	1.44	6.43	0.75	9.85	161.40	908.9
24/02/2026	0	0.80	24.28	9.46	56.99	0.21	0.54	1.50	4.65	0.73	10.19	156.36	908.2
25/02/2026	0	0.88	15.03	9.29	57.21	0.20	0.53	1.40	3.90	0.55	10.28	153.61	888.8
26/02/2026	0	0.90	23.98	9.32	54.85	0.20	0.53	1.31	4.44	0.55	10.11	154.78	893.2
27/02/2026	0	0.93	16.80	9.35	55.48	0.21	0.53	0.99	4.31	0.60	10.21	155.40	888.9
28/02/2026	0	1.01	21.91	9.31	55.38	0.20	0.53	0.81	5.49	0.43	10.38	153.02	868.0
Min	0	0.47	15.03	9.25	48.57	0.20	0.50	0.81	3.43	0.43	9.49	150.98	868.0
Max	0	1.01	25.45	19.00	57.21	0.21	0.54	2.08	9.26	0.75	10.54	164.92	922.7
Sr.	0	0.67	20.23	9.87	52.20	0.21	0.53	1.55	6.19	0.56	9.79	159.48	908.4
PrA3g 2	0	0	0	0	0	0	0	0	0	0			
Wskaznik	0	1.01	21.91	9.31	55.38	0.20	0.53	0.81	5.49	0.43	10.38	153.02	868.0
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					