

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Kwiecień 2026**

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
<b>PrA3g 2</b>	<b>8</b>	<b>40</b>	<b>50</b>	<b>180</b>	<b>1</b>	<b>10</b>	<b>5</b>						
<b>PrA3g 1</b>	<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>			<b>20</b>			
01/04/2026	0	1.31	23.31	10.04	54.57	0.22	0.56	1.68	6.63	1.29	9.74	161.10	912.5
02/04/2026	0	1.45	24.29	10.43	71.25	0.23	0.59	1.96	10.34	1.63	9.85	161.95	917.6
03/04/2026	0	1.50	24.70	10.49	68.30	0.23	0.59	1.80	7.04	1.68	9.87	163.11	919.5
04/04/2026	0	1.30	24.56	10.22	64.20	0.22	0.58	1.93	6.66	1.52	9.83	160.92	913.5
05/04/2026	0	1.31	26.16	10.16	57.56	0.22	0.57	1.73	5.65	1.60	9.81	162.26	908.2
06/04/2026	0	1.06	20.05	9.90	60.45	0.22	0.56	2.23	6.17	1.67	10.99	147.39	906.7
07/04/2026	0	0.93	15.62	9.37	66.49	0.20	0.53	3.45	5.45	0.70	13.38	101.82	892.2
08/04/2026	0	1.27	24.17	10.19	68.34	0.22	0.58	1.84	9.06	1.34	9.74	161.65	913.4
09/04/2026	0	1.40	24.94	10.37	65.89	0.23	0.59	1.75	7.17	1.49	9.83	161.51	917.7
10/04/2026	0	1.01	21.63	9.78	53.63	0.21	0.55	2.18	6.47	1.32	10.21	155.19	907.8
11/04/2026	0	0.94	23.96	9.65	49.74	0.21	0.55	1.63	6.70	1.41	9.55	160.19	912.9
12/04/2026	0	1.36	24.18	10.24	65.29	0.22	0.58	1.72	7.38	1.69	9.81	160.92	915.3
13/04/2026	0	1.50	24.29	10.44	67.73	0.23	0.59	2.06	7.75	1.68	10.00	159.77	912.7
14/04/2026	0	0.89	14.42	9.58	56.41	0.21	0.54	1.99	6.02	1.16	10.18	117.17	903.6
15/04/2026	0	0.99	25.43	9.75	51.70	0.21	0.55	1.63	7.51	1.37	9.83	159.58	896.4
16/04/2026	0	1.36	26.62	10.36	63.47	0.23	0.59	1.46	9.99	1.59	9.98	160.48	899.7
17/04/2026	0	0.78	22.27	9.37	52.07	0.21	0.53	1.55	4.74	1.41	9.63	158.33	905.0
18/04/2026	0	1.37	23.84	10.24	66.15	0.22	0.58	1.51	6.66	1.50	9.90	159.59	911.9
19/04/2026	0	1.62	23.92	10.75	70.32	0.23	0.60	1.78	6.96	1.61	10.06	161.11	918.5
20/04/2026	0	1.49	23.18	10.57	67.43	0.23	0.59	1.79	6.13	1.57	10.01	161.37	917.9
21/04/2026	0	1.58	24.58	10.53	71.67	0.23	0.60	1.75	5.66	1.52	9.95	160.39	920.8
22/04/2026	0	1.60	25.00	10.69	78.13	0.23	0.60	1.58	7.32	1.49	9.92	161.40	922.5
23/04/2026	0	1.20	21.79	9.85	63.05	0.21	0.56	1.63	5.52	1.03	10.25	155.31	901.9
24/04/2026	0	1.49	22.71	10.48	63.14	0.23	0.59	1.73	5.30	1.05	10.07	159.53	917.9
25/04/2026	0	1.61	24.31	10.56	71.14	0.23	0.60	1.76	5.54	1.34	10.05	159.79	920.7
26/04/2026	0	1.59	21.36	10.48	66.24	0.23	0.59	1.72	4.78	1.48	9.98	160.34	920.3
27/04/2026	0	1.41	23.29	10.12	63.97	0.22	0.58	1.84	4.42	1.25	10.10	156.48	905.7
28/04/2026	0	1.31	22.75	10.02	62.41	0.22	0.57	1.71	4.46	1.22	9.86	158.51	912.0
29/04/2026	0	1.63	26.90	10.29	77.89	0.23	0.58	1.73	4.45	1.34	9.81	159.38	921.8
30/04/2026	0	1.63	25.36	10.26	83.72	0.23	0.58	1.70	4.71	1.36	9.75	159.66	920.8
<b>Min</b>	<b>0</b>	<b>0.78</b>	<b>14.42</b>	<b>9.37</b>	<b>49.74</b>	<b>0.20</b>	<b>0.53</b>	<b>1.46</b>	<b>4.42</b>	<b>0.70</b>	<b>9.55</b>	<b>101.82</b>	<b>892.2</b>
<b>Max</b>	<b>0</b>	<b>1.63</b>	<b>26.90</b>	<b>10.75</b>	<b>83.72</b>	<b>0.23</b>	<b>0.60</b>	<b>3.45</b>	<b>10.34</b>	<b>1.69</b>	<b>13.38</b>	<b>163.11</b>	<b>922.5</b>
<b>Sr.</b>	<b>0</b>	<b>1.33</b>	<b>23.32</b>	<b>10.17</b>	<b>64.75</b>	<b>0.22</b>	<b>0.58</b>	<b>1.83</b>	<b>6.42</b>	<b>1.41</b>	<b>10.06</b>	<b>156.21</b>	<b>912.2</b>
<b>PrA3g 2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			
<b>Wskaznik</b>	<b>0</b>	<b>1.63</b>	<b>25.36</b>	<b>10.26</b>	<b>83.72</b>	<b>0.23</b>	<b>0.58</b>	<b>1.70</b>	<b>4.71</b>	<b>1.36</b>	<b>9.75</b>	<b>159.66</b>	<b>920.8</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>					