

## WMK Krakow STUO

### Raport Miesieczny

**Raport miesieczny**
**Maj 2026**

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
<b>PrA3g 2</b>	<b>8</b>	<b>40</b>	<b>50</b>	<b>180</b>	<b>1</b>	<b>10</b>	<b>5</b>	<b>20</b>					
<b>PrA3g 1</b>	<b>60</b>	<b>200</b>	<b>100</b>	<b>400</b>	<b>4</b>	<b>20</b>	<b>30</b>		<b>20</b>				
01/05/2026	0	1.62	25.93	10.24	99.75	0.23	0.58	1.71	5.03	1.46	9.68	161.16	921.1
02/05/2026	0	1.55	22.64	10.14	89.55	0.22	0.58	1.69	4.06	1.55	9.70	161.36	915.9
03/05/2026	0	1.15	24.59	9.50	62.71	0.21	0.54	1.69	2.85	1.49	9.57	160.32	907.7
04/05/2026	0	1.21	24.79	9.60	77.16	0.21	0.55	1.67	3.72	1.42	9.81	159.07	908.0
05/05/2026	0	1.32	22.68	9.80	87.54	0.21	0.56	1.81	4.04	1.65	9.73	161.04	914.1
06/05/2026	0	1.20	20.33	9.88	75.35	0.22	0.56	1.79	2.94	1.32	10.55	153.41	906.5
07/05/2026	0	1.41	24.27	10.77	66.10	0.23	0.59	1.88	3.64	1.47	10.06	160.90	918.3
08/05/2026	0	1.10	23.14	9.73	51.12	0.21	0.55	1.65	2.78	1.36	9.76	160.13	913.1
09/05/2026	0	1.65	25.82	10.55	70.28	0.23	0.59	1.77	3.56	1.61	10.06	161.89	916.1
10/05/2026	0	1.70	25.31	10.43	76.04	0.23	0.59	1.85	3.48	1.76	10.02	163.19	914.4
11/05/2026	0	1.39	23.79	10.20	69.71	0.22	0.58	1.90	2.94	0.74	9.95	162.91	915.9
12/05/2026	0	0.84	21.57	9.63	62.51	0.21	0.55	1.88	2.10	0.27	10.34	145.83	910.1
13/05/2026	0	0.74	25.19	9.48	56.67	0.21	0.54	1.64	2.41	0.27	9.64	162.11	918.4
14/05/2026	0	0.93	21.51	9.72	65.13	0.21	0.55	1.64	1.65	0.31	10.85	151.87	900.5
15/05/2026	0	0.89	26.09	9.62	59.32	0.21	0.55	1.66	2.61	0.26	9.90	160.24	913.9
16/05/2026	0	1.10	24.36	10.07	63.95	0.22	0.57	1.76	3.44	0.76	9.78	164.83	916.7
17/05/2026	0	1.02	18.18	9.99	57.36	0.22	0.56	1.69	2.67	1.06	9.73	165.05	911.4
18/05/2026	0	0.94	22.18	9.91	57.68	0.21	0.55	1.62	2.06	0.50	10.33	158.00	908.2
19/05/2026	0	0.89	26.73	9.62	53.85	0.21	0.54	1.61	2.15	0.34	9.73	160.90	914.6
20/05/2026	0	0.93	26.86	9.82	56.72	0.21	0.55	1.64	2.62	0.28	9.89	159.81	913.1
21/05/2026	0	0.99	24.28	9.86	56.81	0.22	0.56	1.63	2.41	0.27	9.89	159.94	912.5
22/05/2026	0	0.90	24.20	9.76	54.54	0.21	0.55	1.61	2.33	0.26	9.79	160.23	904.1
23/05/2026	0	0.89	24.75	9.47	54.01	0.21	0.54	1.67	1.98	0.26	9.67	160.75	909.6
24/05/2026	0	1.33	24.80	10.15	63.02	0.22	0.58	1.78	3.95	0.26	10.10	161.42	904.5
25/05/2026	0	0.97	19.31	9.58	54.13	0.21	0.54	1.64	2.76	0.26	9.81	160.79	903.0
26/05/2026	0	1.10	22.31	9.78	56.01	0.21	0.55	1.71	3.99	0.90	9.95	161.30	904.0
27/05/2026	0	1.06	21.05	9.64	56.22	0.21	0.55	1.59	2.94	1.65	10.01	159.80	897.6
28/05/2026	0	1.17	22.87	9.60	54.82	0.21	0.54	1.35	3.11	1.60	10.10	158.41	898.0
29/05/2026	0	1.13	26.43	9.57	52.82	0.21	0.54	1.31	4.06	1.93	9.90	160.45	900.9
30/05/2026	0	1.06	25.41	9.64	54.09	0.21	0.55	1.29	3.66	2.23	9.94	160.37	904.2
31/05/2026	0	1.23	23.60	9.77	55.62	0.21	0.56	1.30	4.31	2.37	9.93	161.42	908.3
<b>Min</b>	<b>0</b>	<b>0.74</b>	<b>18.18</b>	<b>9.47</b>	<b>51.12</b>	<b>0.21</b>	<b>0.54</b>	<b>1.29</b>	<b>1.65</b>	<b>0.26</b>	<b>9.57</b>	<b>145.83</b>	<b>897.6</b>
<b>Max</b>	<b>0</b>	<b>1.70</b>	<b>26.86</b>	<b>10.77</b>	<b>99.75</b>	<b>0.23</b>	<b>0.59</b>	<b>1.90</b>	<b>5.03</b>	<b>2.37</b>	<b>10.85</b>	<b>165.05</b>	<b>921.1</b>
<b>Sr.</b>	<b>0</b>	<b>1.14</b>	<b>23.71</b>	<b>9.86</b>	<b>63.57</b>	<b>0.21</b>	<b>0.56</b>	<b>1.66</b>	<b>3.10</b>	<b>1.03</b>	<b>9.94</b>	<b>159.96</b>	<b>909.8</b>
<b>PrA3g 2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			
<b>Wskaznik</b>	<b>0</b>	<b>1.23</b>	<b>23.60</b>	<b>9.77</b>	<b>55.62</b>	<b>0.21</b>	<b>0.56</b>	<b>1.30</b>	<b>4.31</b>	<b>2.37</b>	<b>9.93</b>	<b>161.42</b>	<b>908.3</b>
<b>PrA3g 1</b>		<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>					