

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny Lipiec 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2		8	40	50	180	1	10	5					
PrA3g 1		60	200	100	400	4	20	30		20			
01/07/2026	0	0.77	27.14	9.56	54.29	0.21	0.54	1.62	3.52	2.12	9.83	162.95	914.3
02/07/2026	0	0.73	26.47	9.57	53.12	0.21	0.55	1.61	3.34	1.95	9.95	161.12	910.7
03/07/2026	0	0.77	26.06	9.56	52.61	0.21	0.54	1.61	3.52	1.90	10.02	160.66	903.2
04/07/2026	0	0.78	26.71	9.50	52.13	0.21	0.54	1.60	3.12	2.00	9.93	160.98	909.6
05/07/2026	0	0.82	26.34	9.55	52.57	0.21	0.54	1.60	2.70	1.93	10.03	160.10	908.8
06/07/2026	0	0.70	25.01	9.49	52.49	0.21	0.54	1.60	2.96	2.00	9.88	161.16	913.7
07/07/2026	0	0.73	23.12	9.53	53.28	0.21	0.54	1.61	3.25	1.89	9.93	161.53	912.2
08/07/2026	0	0.83	23.13	9.43	53.66	0.21	0.54	1.86	4.05	2.01	10.02	158.71	912.6
09/07/2026	0	0.78	25.61	9.41	52.62	0.21	0.54	1.67	4.12	1.94	9.87	161.15	911.5
10/07/2026	0	0.80	23.95	9.29	53.06	0.20	0.53	1.60	3.70	2.02	9.67	162.43	921.4
11/07/2026	0	0.83	25.10	9.35	52.83	0.21	0.53	1.58	3.71	6.49	9.85	161.37	907.8
12/07/2026	0	0.72	24.93	9.27	53.88	0.20	0.53	1.58	3.99	3.50	9.60	163.02	920.4
13/07/2026	0	0.81	24.13	9.32	55.70	0.21	0.54	1.58	3.22	2.50	9.78	162.19	911.2
14/07/2026	0	0.89	26.57	9.41	59.51	0.20	0.54	1.60	4.09	2.83	9.58	164.22	921.8
15/07/2026	0	0.79	24.07	9.26	66.79	0.20	0.52	1.56	3.85	2.31	9.73	161.98	908.2
16/07/2026	0	0.79	23.05	9.22	63.74	0.20	0.52	1.55	3.66	2.59	9.68	163.06	909.7
17/07/2026	0	0.81	23.22	9.35	68.45	0.20	0.53	1.70	4.21	2.91	9.71	163.51	910.7
18/07/2026	0	0.77	26.46	9.23	79.15	0.20	0.52	1.64	4.08	2.62	9.63	164.10	912.3
19/07/2026	0	0.87	27.32	9.19	81.79	0.20	0.54	1.90	3.59	2.44	9.88	160.81	906.0
20/07/2026	0	0.99	26.96	9.20	69.65	0.20	0.52	1.59	3.04	2.31	9.77	161.77	911.7
21/07/2026	0	1.20	25.72	9.14	70.66	0.20	0.52	1.55	2.88	2.34	9.85	160.56	908.3
22/07/2026	0	0.87	27.07	9.16	74.00	0.20	0.52	1.41	2.70	2.49	9.74	161.95	913.5
23/07/2026	0	1.13	15.15	8.98	82.77	0.20	0.51	1.49	4.31	1.41	10.07	157.06	880.7
24/07/2026	0	1.08	23.42	9.04	90.24	0.20	0.52	1.51	5.15	2.58	9.91	159.12	891.2
25/07/2026	0	1.07	21.97	8.98	102.66	0.20	0.51	1.51	4.32	2.34	9.95	158.35	888.3
26/07/2026	0	0.90	24.89	9.03	104.52	0.20	0.52	1.55	4.09	2.77	9.62	162.97	912.2
27/07/2026	0	1.12	25.29	9.01	105.01	0.20	0.51	1.53	3.72	2.43	9.75	161.52	907.0
28/07/2026	0	0.87	23.36	8.92	103.42	0.20	0.51	1.50	3.58	2.98	9.57	162.34	917.3
29/07/2026	0	0.92	22.76	8.87	108.66	0.20	0.52	1.49	3.83	2.91	9.50	162.48	910.4
30/07/2026	0	0.82	25.86	8.92	116.00	0.20	0.50	1.51	4.25	3.23	9.46	164.08	909.6
31/07/2026	0	1.20	26.96	8.80	127.70	0.19	0.50	1.49	4.08	14.51	9.47	163.87	904.2
Min	0	0.70	15.15	8.80	52.13	0.19	0.50	1.41	2.70	1.41	9.46	157.06	880.7
Max	0	1.20	27.32	9.57	127.70	0.21	0.55	1.90	5.15	14.51	10.07	164.22	921.8
Sr.	0	0.88	24.77	9.24	73.13	0.20	0.53	1.59	3.70	2.91	9.78	161.65	909.0
PrA3g 2	0	0	0	0	0	0	0	0		0			
Wskaznik	0	1.20	26.96	8.80	127.70	0.19	0.50	1.49	4.08	14.51	9.47	163.87	904.2
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					