

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny Czerwiec 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2		8	40	50	180	1	10	5					
PrA3g 1		60	200	100	400	4	20	30		20			
01/06/2026	0	1.14	23.19	9.66	55.39	0.21	0.54	1.26	3.58	2.34	9.89	160.85	909.3
02/06/2026	0	0.90	26.31	9.92	57.18	0.22	0.56	1.28	3.70	2.57	10.01	160.95	908.2
03/06/2026	0	1.19	26.31	10.54	75.96	0.23	0.60	1.29	9.74	2.14	10.22	162.10	907.0
04/06/2026	0	0.74	23.06	9.73	53.08	0.21	0.55	1.18	3.97	1.81	9.88	160.68	905.8
05/06/2026	0	1.02	24.72	10.21	60.60	0.22	0.57	1.24	5.63	1.77	10.13	161.18	901.5
06/06/2026	0	1.08	25.34	10.05	57.04	0.22	0.58	1.22	4.93	1.75	10.04	161.27	903.6
07/06/2026	0	1.00	23.08	10.01	55.57	0.22	0.56	1.28	5.04	1.68	10.05	161.12	897.6
08/06/2026	0	0.82	19.70	9.69	51.55	0.21	0.55	1.16	3.21	1.45	12.09	136.63	885.7
09/06/2026	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	13.32	62.09	PIEC O
10/06/2026	0	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	PIEC O	13.02	43.86	PIEC O
11/06/2026	0	1.02	9.71	9.38	81.40	0.21	0.53	3.36	0.91	0.94	11.50	122.31	881.4
12/06/2026	0	0.98	23.79	9.47	55.50	0.21	0.54	1.94	2.98	1.54	10.14	156.70	896.5
13/06/2026	0	0.77	25.66	9.65	54.39	0.21	0.55	1.74	2.87	1.88	10.04	161.23	916.1
14/06/2026	0	0.96	25.52	9.62	58.00	0.21	0.54	1.83	2.69	1.74	10.26	157.96	915.4
15/06/2026	0	0.83	26.12	9.63	56.57	0.21	0.55	1.68	2.67	1.89	10.00	160.62	920.5
16/06/2026	0	1.00	25.22	9.60	57.37	0.21	0.55	1.65	2.43	1.81	10.09	159.72	913.3
17/06/2026	0	0.87	24.90	9.81	55.05	0.22	0.56	1.69	5.04	1.78	10.21	160.26	903.5
18/06/2026	0	0.81	24.30	9.78	56.85	0.21	0.55	1.67	5.95	1.80	10.16	160.60	906.4
19/06/2026	0	0.97	22.01	10.38	61.33	0.23	0.59	1.78	16.07	1.76	10.40	162.71	902.3
20/06/2026	0	0.65	19.55	9.76	56.85	0.21	0.55	1.66	5.45	1.78	10.14	161.54	904.8
21/06/2026	0	0.90	25.19	9.72	57.42	0.21	0.55	1.65	4.51	1.85	10.25	160.47	894.9
22/06/2026	0	0.87	20.11	9.73	57.65	0.21	0.55	1.78	5.60	1.73	10.31	158.90	897.0
23/06/2026	0	0.86	24.80	9.66	57.74	0.21	0.55	2.18	4.92	1.86	10.11	162.26	905.7
24/06/2026	0	1.02	24.34	9.54	59.31	0.21	0.54	1.63	3.77	1.94	10.10	161.51	909.1
25/06/2026	0	1.09	25.27	9.58	58.77	0.21	0.53	1.61	4.04	1.95	10.16	161.44	898.6
26/06/2026	0	0.75	24.11	9.62	56.21	0.21	0.53	1.72	4.43	2.34	9.97	163.52	913.1
27/06/2026	0	0.85	23.49	9.72	55.84	0.21	0.57	1.65	4.54	2.30	9.88	165.31	910.8
28/06/2026	0	1.00	25.84	9.85	55.52	0.22	0.58	1.68	4.37	2.75	9.84	167.49	912.2
29/06/2026	0	0.75	26.24	9.56	53.66	0.21	0.54	1.63	4.52	2.47	9.81	166.36	905.0
30/06/2026	0	0.93	28.71	9.87	55.99	0.22	0.56	1.66	5.10	2.35	10.15	162.31	913.0
Min	0	0.65	9.71	9.38	51.55	0.21	0.53	1.16	0.91	0.94	9.81	43.86	881.4
Max	0	1.19	28.71	10.54	81.40	0.23	0.60	3.36	16.07	2.75	13.32	167.49	920.5
Sr.	0	0.92	23.81	9.78	58.14	0.21	0.55	1.65	4.74	1.93	10.41	152.13	904.9
PrA3g 2	0	0	0	0	0	0	0	0		0			
Wskaznik	0	0.93	28.71	9.87	55.99	0.22	0.56	1.66	5.10	2.35	10.15	162.31	913.0
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					