

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny Sierpień 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2		8	40	50	180	1	10	5					
PrA3g 1		60	200	100	400	4	20	30		20			
01/08/2026	0	1.14	25.17	8.76	133.05	0.19	0.50	1.49	3.66	11.52	9.39	165.36	911.6
02/08/2026	0	0.98	26.86	8.80	129.12	0.19	0.51	1.48	3.33	9.07	9.39	163.74	915.2
03/08/2026	0	0.91	25.83	8.85	124.99	0.20	0.50	1.50	3.45	4.81	9.39	164.97	913.1
04/08/2026	0	0.87	26.77	8.85	125.63	0.19	0.51	1.50	3.36	3.50	9.37	165.66	913.3
05/08/2026	0	0.85	26.76	8.82	129.97	0.19	0.51	1.50	3.41	3.33	9.33	166.47	911.4
06/08/2026	0	1.02	26.62	8.82	131.91	0.19	0.51	1.49	3.71	3.11	9.41	165.62	909.8
07/08/2026	0	1.11	28.02	8.79	132.63	0.19	0.51	1.47	3.72	2.47	9.46	161.91	912.9
08/08/2026	0	1.06	24.79	8.66	127.81	0.19	0.50	1.43	4.06	1.76	9.83	156.31	882.5
09/08/2026	0	1.20	26.88	8.68	124.91	0.19	0.49	1.44	3.40	2.35	9.67	158.35	898.7
10/08/2026	0	1.30	27.78	8.67	128.45	0.19	0.50	1.45	2.98	2.60	9.54	160.55	910.2
11/08/2026	0	1.23	27.21	8.57	129.64	0.19	0.49	1.43	2.95	2.43	9.59	159.16	908.4
12/08/2026	0	1.08	26.88	8.71	116.22	0.19	0.50	1.71	3.34	1.76	10.53	146.98	890.6
13/08/2026	0	0.99	26.35	8.95	93.28	0.20	0.52	1.64	5.53	2.22	9.88	155.51	906.8
14/08/2026	0	1.18	24.68	8.92	95.52	0.20	0.50	1.51	5.68	2.29	9.79	157.68	901.6
15/08/2026	0	1.18	24.62	8.87	106.27	0.20	0.50	1.64	5.51	2.47	10.16	154.79	905.8
16/08/2026	0	1.26	27.25	8.81	111.78	0.19	0.49	1.50	4.55	2.69	9.72	159.01	908.8
17/08/2026	0	1.23	26.98	8.79	118.55	0.19	0.50	1.49	4.05	2.51	9.75	157.72	907.0
18/08/2026	0	1.15	27.27	8.73	124.63	0.19	0.50	1.47	3.44	2.35	9.83	156.99	906.9
19/08/2026	0	1.24	27.07	8.75	125.93	0.19	0.50	1.48	4.82	2.18	9.79	157.71	899.8
20/08/2026	0	1.27	25.17	8.70	132.05	0.19	0.50	1.47	4.47	2.20	9.68	158.89	902.4
21/08/2026	0	1.35	25.71	8.68	137.53	0.19	0.49	1.46	4.11	2.05	9.59	158.76	907.4
22/08/2026	0	1.09	25.93	8.65	136.81	0.19	0.49	1.45	3.24	2.12	9.80	157.82	903.4
23/08/2026	0	1.15	25.65	8.58	133.15	0.19	0.49	1.42	5.68	1.82	9.61	157.95	903.7
24/08/2026	0	1.15	25.45	8.51	135.16	0.19	0.48	1.40	4.11	1.98	9.54	157.92	906.9
25/08/2026	0	1.24	24.84	8.55	134.85	0.19	0.49	1.42	3.82	2.09	9.50	158.38	916.5
26/08/2026	0	1.28	26.12	8.54	136.26	0.19	0.48	1.42	4.25	2.27	9.48	159.15	912.5
27/08/2026	0	1.26	26.66	8.61	127.02	0.19	0.49	1.43	4.99	2.21	9.51	159.11	908.8
28/08/2026	0	1.20	24.41	8.67	124.31	0.19	0.49	1.45	4.15	2.25	9.64	159.13	905.5
29/08/2026	0	1.17	24.86	8.71	125.35	0.19	0.49	1.57	3.44	2.16	9.89	157.48	904.5
30/08/2026	0	1.26	25.10	8.69	130.95	0.19	0.51	1.48	4.16	2.08	9.68	158.78	900.3
31/08/2026	0	1.19	24.41	8.63	136.86	0.19	0.50	1.47	4.04	2.15	9.63	159.67	901.8
Min	0	0.85	24.41	8.51	93.28	0.19	0.48	1.40	2.95	1.76	9.33	146.98	882.5
Max	0	1.35	28.02	8.95	137.53	0.20	0.52	1.71	5.68	11.52	10.53	166.47	916.5
Sr.	0	1.15	26.07	8.72	125.83	0.19	0.50	1.49	4.05	2.93	9.66	159.28	906.1
PrA3g 2	0	0	0	0	0	0	0	0	0	0			
Wskaznik	0	1.19	24.41	8.63	136.86	0.19	0.50	1.47	4.04	2.15	9.63	159.67	901.8
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					