

WMK Krakow STUO

Raport Miesieczny

Raport miesieczny Wrzesień 2026

Jedn.	ANALIZATOR : gaz 11% O2										PROCES		
	Select Analyzer	HCL	SO2	CO30m	NOX	HF	COT	Pyl	NH3	Hg	O2 Sec	Temperatur	T2S
		mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	ug/Nm3	%	degreC	degreC
PrA3g 2		8	40	50	180	1	10	5					
PrA3g 1		60	200	100	400	4	20	30		20			
01/09/2026	0	1.03	21.78	8.90	123.82	0.20	0.51	1.46	1.42	1.52	11.00	141.95	899.6
02/09/2026	0	1.00	27.03	9.07	92.58	0.20	0.52	1.53	5.24	2.42	9.81	159.40	909.9
03/09/2026	0	1.23	26.13	8.99	98.57	0.20	0.51	1.51	5.32	2.27	9.85	158.67	901.5
04/09/2026	0	1.21	26.25	8.87	106.71	0.20	0.50	1.49	4.87	2.21	9.84	158.78	902.4
05/09/2026	0	1.22	25.86	8.79	111.50	0.19	0.50	1.48	4.23	2.22	9.85	160.50	903.1
06/09/2026	0	1.13	25.70	8.72	112.27	0.19	0.50	1.45	4.05	2.27	9.79	159.02	905.1
07/09/2026	0	1.19	24.18	8.66	118.31	0.19	0.50	1.43	4.14	1.99	9.70	157.61	901.5
08/09/2026	0	1.16	23.19	8.94	91.00	0.20	0.63	1.55	3.80	1.99	10.07	155.60	901.5
09/09/2026	0	1.05	26.46	9.25	65.68	0.20	0.55	1.58	5.46	2.57	10.01	160.09	904.5
10/09/2026	0	1.13	24.61	9.03	71.83	0.20	0.51	1.51	5.69	2.19	10.05	157.64	902.2
11/09/2026	0	1.16	27.28	9.01	70.80	0.20	0.52	1.50	5.52	2.19	10.03	156.82	899.9
12/09/2026	0	1.15	25.59	9.00	71.54	0.20	0.51	1.49	6.39	2.13	10.03	156.92	895.5
13/09/2026	0	1.05	24.33	8.99	71.80	0.20	0.52	1.48	6.91	1.78	10.19	155.02	883.9
14/09/2026	0	1.01	24.65	9.06	73.85	0.20	0.52	1.49	6.18	1.78	10.34	154.39	878.0
15/09/2026	0	1.02	26.75	9.01	74.88	0.20	0.51	1.48	6.42	2.12	10.23	155.76	882.9
16/09/2026	0	1.13	25.99	9.06	76.89	0.20	0.53	1.51	8.07	2.21	10.20	157.16	884.4
17/09/2026	0	1.14	25.60	8.99	78.30	0.20	0.57	1.50	6.10	2.46	10.13	158.04	895.6
18/09/2026	0	1.18	25.74	9.06	79.90	0.20	0.52	1.52	5.01	2.71	10.01	159.29	904.6
19/09/2026	0	1.14	24.87	8.96	77.56	0.20	0.52	1.49	5.00	2.45	10.01	159.04	898.0
20/09/2026	0	1.13	24.81	8.93	77.79	0.20	0.52	1.49	3.92	2.85	10.01	159.33	899.1
21/09/2026	0	1.08	26.95	8.97	79.45	0.20	0.51	1.49	3.39	2.68	10.20	159.11	895.6
22/09/2026	0	1.12	25.35	8.93	79.85	0.20	0.51	1.49	3.31	2.68	10.10	159.57	903.6
23/09/2026	0	1.17	27.03	8.92	80.23	0.20	0.51	1.50	3.92	2.66	10.03	160.48	898.8
24/09/2026	0	1.05	16.80	9.20	78.15	0.20	0.84	1.52	2.79	1.39	10.87	141.54	902.4
25/09/2026	0	1.18	25.68	9.12	62.36	0.20	0.52	1.51	4.50	2.05	10.15	155.98	890.2
26/09/2026	0	1.18	26.75	9.15	64.90	0.20	0.52	1.52	4.58	2.37	10.02	158.09	901.9
27/09/2026	0	1.03	20.64	9.13	73.27	0.20	0.54	1.59	3.05	1.99	10.34	153.76	901.2
28/09/2026	0	1.22	25.74	9.03	68.37	0.20	0.51	1.52	3.87	2.21	10.02	157.83	899.6
29/09/2026	0	1.22	26.13	9.02	69.88	0.20	0.51	1.51	3.63	2.32	10.02	158.32	899.1
30/09/2026	0	1.21	26.07	9.04	73.21	0.20	0.51	1.51	3.83	2.38	9.99	158.54	897.9
Min	0	1.00	16.80	8.66	62.36	0.19	0.50	1.43	1.42	1.39	9.70	141.54	878.0
Max	0	1.23	27.28	9.25	123.82	0.20	0.84	1.59	8.07	2.85	11.00	160.50	909.9
Sr.	0	1.13	25.13	8.99	82.51	0.20	0.53	1.50	4.69	2.24	10.10	156.81	898.1
PrA3g 2	0	0	0	0	0	0	0	0		0			
Wskaznik	0	1.21	26.07	9.04	73.21	0.20	0.51	1.51	3.83	2.38	9.99	158.54	897.9
PrA3g 1		00:00	00:00	00:00	00:00	00:00	00:00	00:00					